Coolfix Home Services (demo)

Service job card. Air conditioners. Pune.

Job no.: CF-3304

Date: 26 Jun 2026

Customer: G. Nair

Area: Hadapsar

Unit model: Coolwave CS-15F

Serial no.: K80-99736

Complaint: Poor cooling in afternoon

Suction (psi): 138

Compressor (A): 9.4

Supply air (C): 16

Work done: Outdoor coil choked with dust. Coil cleaning advised

Parts used: None

Remarks: Customer declined coil wash

Next service: Dec 2026

Technician: Joseph

☐ Filters cleaned ☐ Gas topped up ☑ Customer informed

Customer signature: Nair