Coolfix Home Services (demo)

Service job card. Air conditioners. Pune.

Job no. CF-5530

Date 6 Apr 2026

Customer A. Kulkarni

Area Aundh

Unit model Arctiq 1.2-R32

Serial no. K62-13311

Complaint: Humming sound outside

Suction (psi): 130

Compressor (A): 7.6

Supply air (C): 14

Work done: Capacitor tested 31 uF (rated 35). Within limit

Parts used: None

Remarks: Capacitor weak, replace soon

Next service: Oct 2026

Technician: Joseph

☐ Filters cleaned ☐ Gas topped up ☑ Customer informed

Customer signature: Kulkarni