Coolfix Home Services (demo)

Service job card. Air conditioners. Pune.

Job no.
CF-6721

Date
5 May 2026

Customer
S. Fernandes

Area
Baner

Unit model
Coolwave CS-15F

Serial no.
M61-68394

Complaint
Display shows wrong temp

Suction (psi)
127

Compressor (A)
6.0

Supply air (C)
13

Work done
Reset unit. Sensor reading checked

Parts used
None

Remarks
Replace room sensor if it repeats

Next service
Nov 2026

Technician
Imran

☐ Filters cleaned ☐ Gas topped up ☑ Customer informed

Customer signature
Fernandes