

MAINTENANCE & REPAIR REPORT

Plant Engineering Dept. · Form ME-07 Rev C

REPORT NO.

RPT-4007

FAULT PATTERN ID

FP-02

DATE OF FAILURE

17/07/2024 11:00

ASSET ID

AST-003

MODEL NO.

ATLAS-GA30

LINKED WO

-

SYMPTOMS OBSERVED

Comp running 78C vs 71C normal, vib normal. Cooler fins packed with dust.

DIAGNOSIS / ROOT CAUSE

Blocked cooler, ambient dust ingress

PARTS REPLACED

COIL-CLEAN-KIT

DOWNTIME (HRS)

3.0

FAULT CATEGORY

Cooling Degradation

TECHNICIAN

V. Gawas

SIGNATURE

