

MAINTENANCE & REPAIR REPORT

Plant Engineering Dept. · Form ME-07 Rev C

REPORT NO.

RPT-4012

FAULT PATTERN ID

FP-03

DATE OF FAILURE

21/02/2026 01:00

ASSET ID

AST-002

MODEL NO.

KSB-ETN-080

LINKED WO

-

SYMPTOMS OBSERVED

Temp reading stuck 55.0 for 3 shifts, pump normal on touch. RTD open circuit intermittent.

DIAGNOSIS / ROOT CAUSE

RTD lead fatigue at terminal head

PARTS REPLACED

CBL-M12-5M

DOWNTIME (HRS)

1.5

FAULT CATEGORY

Sensor Fault

TECHNICIAN

P. Fernandes

SIGNATURE

