Maintenance Schedule

PowerPack®
6 H 1800 R83P
6 H 1800 R85
Application Group 2A

MS50101/00E

Power. Passion. Partnership.

6H1800R83P
6H1800R85

Table 1: applicable for

This handbook is provided for use by maintenance and operating personnel in order to avoid malfunctions or damage during operation.

Subject to alterations and amendments.

1 Maintenance Schedule

1.1 Preface

MTU maintenance concept

The maintenance system for MTU products is based on a preventive maintenance concept. Preventive maintenance facilitates advance planning and ensures a high level of equipment availability.

The maintenance schedule is based on the load profile / load factor specified below. The time intervals at which the maintenance work is to be carried out and the relevant checks and tasks involved are average values based on operational experience and are therefore to be regarded as guidelines only. Special operating conditions and technical requirements may require additional maintenance work and/or modification of the maintenance intervals. The intervals according to which the maintenance tasks have to be carried out are specified as operating hours and time limits. The limit which occurs first is applicable. In order to be authorized to carry out the individual maintenance jobs, maintenance personnel must have achieved a level of training and qualification appropriate to the complexity of the task in hand. The various Qualification Levels QL1 to QL4 reflect the levels of training offered in MTU courses and the contents of the tool kits required:

QL1: Operational monitoring and maintenance which can be carried out during a break in operation without disassembling the PowerPack.
QL2: Component exchange (corrective only).
QL3: Maintenance work which requires partial disassembly of the PowerPack.
QL4: Maintenance work which requires complete disassembly of the PowerPack.

The maintenance schedule matrix normally finishes with extended component maintenance. Following this, maintenance work is to be continued at the intervals indicated.

The numbers stated in the list of jobs provide a reference to the scope of parts required.

Notes on maintenance

Specifications for fluids and lubricants, guideline values for their maintenance and change intervals and lists of recommended fluids and lubricants are contained in the MTU Fluids and Lubricants Specifications A001062 and in the fluids and lubricants specifications produced by the component manufacturers. They are therefore not included in the maintenance schedule (exception: deviations from the Fluids and Lubricants Specifications). All fluids and lubricants used must meet MTU specifications and be approved by the relevant component manufacturer.

Amongst other items, the operator/customer must carry out the following additional maintenance work:
- Protect components made of rubber or synthetic material from oil. Never treat them with organic detergents. Wipe with a dry cloth only.
- Fuel prefilter:
  The maintenance interval depends on how dirty the fuel is. The paper inserts in fuel prefilters must be changed every two years at the latest (Task 9998).
- Battery:
  Battery maintenance depends on the level of use and the ambient conditions. The battery manufacturer's instructions must be obeyed.

The relevant manufacturer's instructions apply with respect to the maintenance of any components which do not appear in this maintenance schedule.

This Maintenance Schedule may include components which are not included in the MTU supply scope; these may be disregarded.

Out-of-service-periods

If the engine is to remain out of service for more than 1 month, carry out engine preservation procedures in accordance with the Fluids and Lubricants Specifications, MTU Publication No. A001062.

TIM-ID: 0000000002 - 001

Application Group

2A	Continuous operation, unrestricted

Load profile

Load	100%	90%	75%	<15%		
Corresponding operating time	30%	10%	10%	50%		
Full-load switching	(≤10% to ≥90% target value): ≤15/h					

TIM-ID: 0000000002 - 001