| Aenderungsbeschreibung/Description of Revision | Kommt vor/Frequency |
|---|---|
| war kZ | |

| Buchst./Rev.Ltr. | Aenderungs-Nr./Revision Notice No. | Bearbeitungsstatus/Lifecycle |
|---|---|---|
| -.17 | PR047871 | Released |

| |
|---|
| **Changes from Var1 Ed 01.00 to Var1 Ed 01.02** |
| |
| **Corrections:** |
| CANID 562/714 changed from HI to LO (P-FuelPrefilter) |
| CANID 603 content changed from ECU alarms to MMS alarms (all devices) |
| SCR alarms/measuring points renamed |
| **New measuring points added:** |
| CANID 605 added (T-ExhaustSCROutlet2) |
| **New limits added:** |
| CANID 583 Item added (LM AL RA Tank Level Empty) |
| CANID 605 added (LM LOLO P-Raw Water) |
| **New alarms added:** |

AL Permanent Injection Rail2
AL MMS Combined Red
AL MMS Combined Yel
AL RA Tank Level Empty
SD Lube Oil Level Switch
LOLO P-Raw Water
AL Gas Inclusion
SD P-Coolant Intercooler
LO P-Coolant Intercooler
LOLO P-Coolant Intercooler
SD P-Intake Air After FilterA
LO P-Intake Air After FilterA
LOLO P-Intake AirAfterFilterA
SD P-Intake Air After FilterB
LO P-Intake Air After FilterB
LOLO P-Intake AirAfterFilterB
SD T-Coolant Intercooler
HI T-Coolant Intercooler
HIHI T-Coolant Intercooler
AL Inj. Drift Limit 1 Cyl.A1
AL Inj. Drift Limit 1 Cyl.A2
AL Inj. Drift Limit 1 Cyl.A3
AL Inj. Drift Limit 1 Cyl.A4
AL Inj. Drift Limit 1 Cyl.A5
AL Inj. Drift Limit 1 Cyl.A6
AL Inj. Drift Limit 1 Cyl.A7
AL Inj. Drift Limit 1 Cyl.A8
AL Inj. Drift Limit 1 Cyl.A9
AL Inj. Drift Limit 1 Cyl.A10
AL Inj. Drift Limit 2 Cyl.A1
AL Inj. Drift Limit 2 Cyl.A2
AL Inj. Drift Limit 2 Cyl.A3
AL Inj. Drift Limit 2 Cyl.A4
AL Inj. Drift Limit 2 Cyl.A5
AL Inj. Drift Limit 2 Cyl.A6
AL Inj. Drift Limit 2 Cyl.A7
AL Inj. Drift Limit 2 Cyl.A8
AL Inj. Drift Limit 2 Cyl.A9
AL Inj. Drift Limit 2 Cyl.A10

Allgemeintoleranzen/General Tolerances ISO 2768-mK

Tolerierung/Tolerancing ISO 8015 | Masse/Size ISO 14405

Masse/Mass kg | Format/Size **A4**

Ausf. u.Lieferung Tech. Characteristics

Oberflaechenschutz Surface Protection

Oberflaechenangaben nach MTN5033
Surface Specification per MTN5033

Werkstoff
Material

Halbzeug,Modell Gesenk
Semifinished Product
Pattern, Die

Verwendbar f.Typ / Applicable to Model: GLNG Release 10

Allgemeine Fertigungsvorschriften nach MMN332
Production Specification per MMN 332

Projekt-/Auftrags-Nr.
Project/Order No.

Material-Nr./Material No.

XZ00E52000015

Ref.-Nr./ Ref. No.: Type1 Var01 ED01_00 | Emission ID



| WORD | Datum/Date | Name |
|---|---|---|
| Erstell. Drawn | 2018-09-10 12:16:34 | schaepers |
| Bearb. Change | 2019-09-11 09:44:48 | schaepers |
| Norm Std. | 2019-09-11 09:44:48 | ihmor stef |
| Gepr. Checked | 2019-09-11 09:44:48 | ihmor stef |

Benennung/ Title /

# DOKUMENTATION

**GLNG Fremdschnittstelle CANopen** **Genoline | NewGeneration**

# DOCUMENTATION

**GLNG Foreign MCS CANopen**

MTU Friedrichshafen GmbH

Zeichnungs-Nr./Drawing No. **ZNG00019137**

Beschreibung/Description Type1 Var01 ED01_02

Blatt/ Sheet **1** von/of **32**

T-468-0107

| Aenderungsbeschreibung/Description of Revision | | Kommt vor/Frequency |
|---|---|---|
| war kZ | | |
| Buchst./Rev.Ltr. | Aenderungs-Nr./Revision Notice No. | Bearbeitungsstatus/Lifecycle |
| -.17 | PR047871 | Released |

AL Inj. Drift Limit 1 Cyl.B1
AL Inj. Drift Limit 1 Cyl.B2
AL Inj. Drift Limit 1 Cyl.B3
AL Inj. Drift Limit 1 Cyl.B4
AL Inj. Drift Limit 1 Cyl.B5
AL Inj. Drift Limit 1 Cyl.B6
AL Inj. Drift Limit 1 Cyl.B7
AL Inj. Drift Limit 1 Cyl.B8
AL Inj. Drift Limit 1 Cyl.B9
AL Inj. Drift Limit 1 Cyl.B10
AL Inj. Drift Limit 2 Cyl.B1
AL Inj. Drift Limit 2 Cyl.B2
AL Inj. Drift Limit 2 Cyl.B3
AL Inj. Drift Limit 2 Cyl.B4
AL Inj. Drift Limit 2 Cyl.B5
AL Inj. Drift Limit 2 Cyl.B6
AL Inj. Drift Limit 2 Cyl.B7
AL Inj. Drift Limit 2 Cyl.B8
AL Inj. Drift Limit 2 Cyl.B9
AL Inj. Drift Limit 2 Cyl.B10
HI ETC Idle Speed
LO RA Concentration
LOLO RA Concentration
SD RA Concentration
HI RA Concentration
HIHI RA Concentration
LO RA Quality
HI P-Exhaust Diff SCR2
HIHI P-Exhaust Diff SCR2
SD T-Exhaust SCR Outlet2
HI T-Exhaust SCR Outlet2
HIHI T-Exhaust SCR Outlet2
AL PFM Leak Check Failed
HI T-Reducing Agent SUDU F1
HI T-Reducing Agent SUDU F2
AL Hydraulics Fault SUDU1
AL Hydraulics Fault SUDU2
AL Hydraulics Fault SUDU3
AL Hydraulics Fault SUDU4
AL Hydraulics Fault SUDU5
AL Hydraulics Fault SUDU6
AL SD-Card Unaccessible
SD Eng.Speed Crankshaft SaSy
TD Engine Speed Crankshaft
AL Coolant Leakage LT
SD Coolant Leakage LT
AL Oil Refill Tank Empty
SD Oil Refill Tank Empty
AL Com Lost NOx EGAT Outlet 2
SD NOx EGAT Outlet 2
AL Perm. Injection Detection

# PDO Mapping MTU transmit

| PDO Name | CANID | Source Node | Transfer Mode | Repetition Rate | Send On Change Time | Frame Type | DLC |
|---|---|---|---|---|---|---|---|
| Digital Measuring Points 1 | 400 | 0 | 1 | 50 | 0 | 0 | 8 |
| Digital Measuring Points 2 | 401 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 3 | 402 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 4 | 403 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 5 | 404 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 6 | 405 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 7 | 406 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 8 | 407 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 9 | 408 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 10 | 409 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 11 | 410 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 12 | 411 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 13 | 412 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 14 | 413 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 15 | 414 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 16 | 415 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 17 | 416 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 18 | 417 | 0 | 1 | 500 | 0 | 0 | 8 |
| Digital Measuring Points 19 | 418 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 1 | 430 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 2 | 431 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 3 | 432 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 4 | 433 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 5 | 434 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 6 | 435 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 7 | 436 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 8 | 437 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 9 | 438 | 0 | 1 | 500 | 0 | 0 | 8 |
| Pressure Measuring Points 10 | 439 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 1 | 500 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 2 | 501 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 3 | 502 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 4 | 503 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 5 | 504 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 6 | 505 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 7 | 506 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 8 | 507 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 9 | 508 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 10 | 509 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 11 | 510 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 12 | 511 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 13 | 512 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 14 | 513 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 15 | 514 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 16 | 515 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 17 | 516 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 18 | 517 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 19 | 518 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 20 | 519 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 21 | 520 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 22 | 521 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 23 | 522 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 24 | 523 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 25 | 524 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 26 | 525 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 27 | 526 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 28 | 527 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 29 | 528 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 30 | 529 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 31 | 530 | 0 | 1 | 500 | 0 | 0 | 8 |

| Aenderungsbeschreibung/Description of Revision | Kommt vor/Frequency |
|---|---|
| war kZ | |

| Buchst./Rev.Ltr. | Aenderungs-Nr./Revision Notice No. | Bearbeitungsstatus/Lifecycle |
|---|---|---|
| -.17 | PR047871 | Released |

| PDO Name | CANID | Source Node | Transfer Mode | Repetition Rate | Send On Change Time | Frame Type | DLC |
|---|---|---|---|---|---|---|---|
| Temperature Measuring Points 32 | 531 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 33 | 532 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 34 | 533 | 0 | 1 | 500 | 0 | 0 | 8 |
| Temperature Measuring Points 35 | 534 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 1 | 550 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 2 | 551 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 3 | 552 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 4 | 553 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 5 | 554 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 6 | 555 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 7 | 556 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 8 | 557 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 9 | 558 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 10 | 559 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 11 | 560 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 12 | 561 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 13 | 562 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 14 | 563 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 15 | 564 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 16 | 565 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 17 | 566 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 18 | 567 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 19 | 568 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 20 | 569 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 21 | 570 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 22 | 571 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 23 | 572 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 24 | 573 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 25 | 574 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 26 | 575 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 27 | 576 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 28 | 577 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 29 | 578 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 30 | 579 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 31 | 580 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 32 | 581 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 33 | 582 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 34 | 583 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 35 | 584 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 36 | 585 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 37 | 586 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 38 | 587 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 39 | 588 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 40 | 589 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 41 | 590 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 42 | 591 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 43 | 592 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 44 | 593 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 45 | 594 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 46 | 595 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 47 | 596 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 48 | 597 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 49 | 598 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 50 | 599 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 51 | 600 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 52 | 601 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 53 | 602 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 54 | 603 | 0 | 1 | 500 | 0 | 0 | 8 |
| Measuring Point Limits 55 | 604 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Measuring Points 1 | 700 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 1 | 701 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 2 | 702 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 3 | 703 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 4 | 704 | 0 | 1 | 500 | 0 | 0 | 8 |

| PDO Name | CANID | Source Node | Transfer Mode | Repetition Rate | Send On Change Time | Frame Type | DLC |
|---|---|---|---|---|---|---|---|
| Binary Alarms 5 | 705 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 6 | 706 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 7 | 707 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 8 | 708 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 9 | 709 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 10 | 710 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 11 | 711 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 12 | 712 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 13 | 713 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 14 | 714 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 15 | 715 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 16 | 716 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 17 | 717 | 0 | 1 | 500 | 0 | 0 | 8 |
| Binary Alarms 18 | 718 | 0 | 1 | 500 | 0 | 0 | 8 |

# Signal range and interpretation of MTU transmit data

| Non binary signals | |
|---|---|
| Bitsize | 32 |
| CANID | 400-605 |
| Valid range | 0-FAFFFFFFh<br>(-2105540607.5 up to 2105540607.5)<br>Offset: 2105540607 |
| Sensor defect SD | FEFFFFFFh |
| Missing data MD | FFFFFFFFh |

| Binary signals | | |
|---|---|---|
| Bitsize | 2 | |
| CANID | 700 | |
| - | Bit1 | Bit0 |
| Inactive | 0 | 0 |
| Active | 0 | 1 |
| Sensor defect SD | 1 | 0 |
| Missing data MD | 1 | 1 |

| Alarms | | |
|---|---|---|
| Bitsize | 2 | |
| CANID | 701-721 | |
| - | Bit1 | Bit0 |
| Alarm inactive | *Ignore* | 0 |
| Alarm active | *ignore* | 1 |

*Example of „Engine Speed“:*

- actual engine speed: 2890,4 rpm

- CAN raw value: 0x7D8070E7 (=2105569511)

- calculated value less offset: 2105569511-2105540607 = 28904

- divided  by rpm scaling factor 10: 2890,4 rpm

| Aenderungsbeschreibung/Description of Revision | | Kommt vor/Frequency |
|---|---|---|
| war kZ | | |
| Buchst./Rev.Ltr. -.17 | Aenderungs-Nr./Revision Notice No. PR047871 | Bearbeitungsstatus/Lifecycle Released |

# CANID Mapping MTU transmit

| CANID | Signal Name | Alarm Description | Bitsize | Startbyte | Startbit | Unit | Scaling |
|---|---|---|---|---|---|---|---|
| 400 | Engine Speed | - | 32 | 1 | 1 | rpm | 10 |
| | Idle Speed | - | 32 | 5 | 1 | rpm | 10 |
| 401 | Nominal Speed | - | 32 | 1 | 1 | rpm | 10 |
| | Feedback Speed Demand | - | 32 | 5 | 1 | rpm | 10 |
| 402 | Feedback Speed Demand Eff. | - | 32 | 1 | 1 | rpm | 10 |
| | Injection in Relation to DBR | - | 32 | 5 | 1 | % | 1000 |
| 403 | Injection Limitation 0-120% | - | 32 | 1 | 1 | % | 1000 |
| | Trip Fuel Consumption HI | - | 32 | 5 | 1 | l | 10 |
| 404 | Mean Trip Fuel Consumption | - | 32 | 1 | 1 | l/h | 1000 |
| | Trip Duration HI | - | 32 | 5 | 1 | h | 1 |
| 405 | Actual Fuel Consumption | - | 32 | 1 | 1 | l/h | 1000 |
| | Total Fuel Consumption HI | - | 32 | 5 | 1 | l | 10 |
| 406 | Fuel Consumpt Max lh DIS | - | 32 | 1 | 1 | l/h | 1000 |
| | Fuel Consumpt Act DIS | - | 32 | 5 | 1 | % | 1000 |
| 407 | Fuel Cons Mean Trip DIS | - | 32 | 1 | 1 | % | 1000 |
| | Status Start Procedure | - | 32 | 5 | 1 | digit | 1 |
| 408 | Power Supply EIM/Starter Bat. | - | 32 | 1 | 1 | V | 1000 |
| | ECU Power Supply Voltage | - | 32 | 5 | 1 | V | 1000 |
| 409 | ETC 1 Speed | - | 32 | 1 | 1 | krpm | 10000 |
| | ETC 2 Speed | - | 32 | 5 | 1 | krpm | 10000 |
| 410 | ETC 3 Speed | - | 32 | 1 | 1 | krpm | 10000 |
| | ETC 4 Speed | - | 32 | 5 | 1 | krpm | 10000 |
| 411 | ECU Operat.Hours | - | 32 | 1 | 1 | sec | 1 |
| | ECU Failure Codes | - | 32 | 5 | 1 | digit | 1 |
| 412 | Engine Speed SaSy | - | 32 | 1 | 1 | rpm | 10 |
| | RA Tank Level Norm | - | 32 | 5 | 1 | % | 1000 |
| 413 | UserInstruction | - | 32 | 1 | 1 | digit | 1 |
| | UTC Seconds | - | 32 | 5 | 1 | digit | 1 |
| 414 | UTC Minutes | - | 32 | 1 | 1 | digit | 1 |
| | UTC Hour | - | 32 | 5 | 1 | digit | 1 |
| 415 | Day | - | 32 | 1 | 1 | digit | 1 |
| | Month | - | 32 | 5 | 1 | digit | 1 |
| 416 | Year | - | 32 | 1 | 1 | digit | 1 |
| | Alarmmanagement Group Static | - | 32 | 5 | 1 | digit | 1 |
| 417 | Alarmmanagement Group Dynamic | - | 32 | 1 | 1 | digit | 1 |
| | Power Actual Gen | - | 32 | 5 | 1 | kW | 1000 |
| 418 | Engine Load Reserve | - | 32 | 1 | 1 | % | 1000 |
| | Injection Quantity 0-120 | - | 32 | 5 | 1 | % | 1000 |

| CANID | Signal Name | Alarm Description | Bitsize | Startbyte | Startbit | Unit | Scaling |
|---|---|---|---|---|---|---|---|
| 430 | P-Start Air | - | 32 | 1 | 1 | bar | 100000 |
| | P-Charge Air A | - | 32 | 5 | 1 | bar | 100000 |
| 431 | P-Crankcase | - | 32 | 1 | 1 | mbar | 100 |
| | P-Coolant | - | 32 | 5 | 1 | bar | 100000 |
| 432 | P-Raw Water | - | 32 | 1 | 1 | bar | 100000 |
| | P-Fuel | - | 32 | 5 | 1 | bar | 100000 |
| 433 | P-Fuel before Filter (ECU) | - | 32 | 1 | 1 | bar | 100000 |
| | P-Fuel Filter Difference | - | 32 | 5 | 1 | bar | 100000 |
| 434 | P-Fuel Prefilter Diff. | - | 32 | 1 | 1 | bar | 100000 |
| | P-Lube Oil aft. Filter (ECU) | - | 32 | 5 | 1 | bar | 100000 |
| 435 | P-Lube Oil before Filter (ECU) | - | 32 | 1 | 1 | bar | 100000 |
| | P-Oil Filter Difference | - | 32 | 5 | 1 | bar | 100000 |
| 436 | P-Lube Oil A-Side ETCs | - | 32 | 1 | 1 | bar | 100000 |
| | P-Lube Oil B-Side ETCs | - | 32 | 5 | 1 | bar | 100000 |
| 437 | P-Oil Refill Pump | - | 32 | 1 | 1 | bar | 100000 |
| | P-Lube Oil aft. Filter SaSy | - | 32 | 5 | 1 | bar | 100000 |
| 438 | P-Exhaust Diff SCR1 | - | 32 | 1 | 1 | bar | 100000 |
| | P-RA Filter Out At PFM | - | 32 | 5 | 1 | bar | 100000 |
| 439 | P-Fuel Prefilter | - | 32 | 1 | 1 | bar | 100000 |
| | P-Exhaust Back | - | 32 | 5 | 1 | mbar | 100 |
| 500 | T-Intake Air | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust A1 | - | 32 | 5 | 1 | degC | 100 |
| 501 | T-Exhaust A2 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust A3 | - | 32 | 5 | 1 | degC | 100 |
| 502 | T-Exhaust A4 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust A5 | - | 32 | 5 | 1 | degC | 100 |
| 503 | T-Exhaust A6 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust A7 | - | 32 | 5 | 1 | degC | 100 |
| 504 | T-Exhaust A8 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust A9 | - | 32 | 5 | 1 | degC | 100 |
| 505 | T-Exhaust A10 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust B1 | - | 32 | 5 | 1 | degC | 100 |
| 506 | T-Exhaust B2 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust B3 | - | 32 | 5 | 1 | degC | 100 |
| 507 | T-Exhaust B4 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust B5 | - | 32 | 5 | 1 | degC | 100 |
| 508 | T-Exhaust B6 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust B7 | - | 32 | 5 | 1 | degC | 100 |
| 509 | T-Exhaust B8 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust B9 | - | 32 | 5 | 1 | degC | 100 |

| CANID | Signal Name | Alarm Description | Bitsize | Startbyte | Startbit | Unit | Scaling |
|---|---|---|---|---|---|---|---|
| 510 | T-Exhaust B10 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust Mean | - | 32 | 5 | 1 | degC | 100 |
| 511 | T-Exhaust Combined A | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust before ETC (Combined B) | - | 32 | 5 | 1 | degC | 100 |
| 512 | T-Exhaust Combined C | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust Combined D | - | 32 | 5 | 1 | degC | 100 |
| 513 | T-Charge Air A | - | 32 | 1 | 1 | degC | 100 |
| | T-Charge Air Seq Ctrl Valve | - | 32 | 5 | 1 | degC | 100 |
| 514 | T-Coolant (ECU) | - | 32 | 1 | 1 | degC | 100 |
| | T-Fuel Common Rail A | - | 32 | 5 | 1 | degC | 100 |
| 515 | T-Lube Oil | - | 32 | 1 | 1 | degC | 100 |
| | T-Lube Oil ETC | - | 32 | 5 | 1 | degC | 100 |
| 516 | T-Splash Oil B1 | - | 32 | 1 | 1 | degC | 100 |
| | T-Splash Oil B2 | - | 32 | 5 | 1 | degC | 100 |
| 517 | T-Splash Oil B3 | - | 32 | 1 | 1 | degC | 100 |
| | T-Splash Oil B4 | - | 32 | 5 | 1 | degC | 100 |
| 518 | T-Splash Oil B5 | - | 32 | 1 | 1 | degC | 100 |
| | T-Splash Oil B6 | - | 32 | 5 | 1 | degC | 100 |
| 519 | T-Splash Oil B7 | - | 32 | 1 | 1 | degC | 100 |
| | T-Splash Oil B8 | - | 32 | 5 | 1 | degC | 100 |
| 520 | T-Splash Oil B9 | - | 32 | 1 | 1 | degC | 100 |
| | T-Splash Oil B10 | - | 32 | 5 | 1 | degC | 100 |
| 521 | T-Bearing 1 | - | 32 | 1 | 1 | degC | 100 |
| | T-Bearing 2 | - | 32 | 5 | 1 | degC | 100 |
| 522 | T-Bearing 3 | - | 32 | 1 | 1 | degC | 100 |
| | T-Bearing 4 | - | 32 | 5 | 1 | degC | 100 |
| 523 | T-Bearing 5 | - | 32 | 1 | 1 | degC | 100 |
| | T-Bearing 6 | - | 32 | 5 | 1 | degC | 100 |
| 524 | T-Bearing 7 | - | 32 | 1 | 1 | degC | 100 |
| | T-Bearing 8 | - | 32 | 5 | 1 | degC | 100 |
| 525 | T-Bearing 9 | - | 32 | 1 | 1 | degC | 100 |
| | T-Bearing 10 | - | 32 | 5 | 1 | degC | 100 |
| 526 | T-Bearing 11 | - | 32 | 1 | 1 | degC | 100 |
| | T-Bearing Mean | - | 32 | 5 | 1 | degC | 100 |
| 527 | T-ECU | - | 32 | 1 | 1 | degC | 100 |
| | T-Coolant SaSy | - | 32 | 5 | 1 | degC | 100 |
| 528 | T-Exhaust SCR Inlet1 | - | 32 | 1 | 1 | degC | 100 |
| | T-Exhaust SCR Inlet2 | - | 32 | 5 | 1 | degC | 100 |
| 529 | T-Exhaust SCR Outlet1 | - | 32 | 1 | 1 | degC | 100 |
| | T-Reducing Agent At PFM | - | 32 | 5 | 1 | degC | 100 |

| Aenderungsbeschreibung/Description of Revision | Kommt vor/Frequency |
|---|---|
| war kZ | |

| Buchst./Rev.Ltr. | Aenderungs-Nr./Revision Notice No. | Bearbeitungsstatus/Lifecycle |
|---|---|---|
| -.17 | PR047871 | Released |

| CANID | Signal Name | Alarm Description | Bitsize | Startbyte | Startbit | Unit | Scaling |
|---|---|---|---|---|---|---|---|
| 530 | T-AirInlet Gen | - | 32 | 1 | 1 | degC | 100 |
| | T-AirOutlet Gen | - | 32 | 5 | 1 | degC | 100 |
| 531 | T-Bearing GenDE | - | 32 | 1 | 1 | degC | 100 |
| | T-Bearing GenNDE | - | 32 | 5 | 1 | degC | 100 |
| 532 | T-WindingL1 Gen | - | 32 | 1 | 1 | degC | 100 |
| | T-WindingL2 Gen | - | 32 | 5 | 1 | degC | 100 |
| 533 | T-WindingL3 Gen | - | 32 | 1 | 1 | degC | 100 |
| | T-Coolant Gen Out | - | 32 | 5 | 1 | degC | 100 |
| 534 | T-Coolant Gen In | - | 32 | 1 | 1 | degC | 100 |
| | T-Splash Oil Mean | - | 32 | 5 | 1 | degC | 100 |
| 550 | LM LO RA Tank Level | - | 32 | 1 | 1 | % | 1000 |
| | LM LOLO RA Tank Level | - | 32 | 5 | 1 | % | 1000 |
| 551 | LM LO P-Start Air | - | 32 | 1 | 1 | bar | 100000 |
| | LM LOLO P-Start Air | - | 32 | 5 | 1 | bar | 100000 |
| 552 | LM HI P-Charge Air A | - | 32 | 1 | 1 | bar | 100000 |
| | LM LO P-Coolant | - | 32 | 5 | 1 | bar | 100000 |
| 553 | LM LOLO P-Coolant | - | 32 | 1 | 1 | bar | 100000 |
| | LM LO P-Raw Water | - | 32 | 5 | 1 | bar | 100000 |
| 554 | LM LO P-Fuel | - | 32 | 1 | 1 | bar | 100000 |
| | LM LOLO P-Fuel | - | 32 | 5 | 1 | bar | 100000 |
| 555 | LM HI P-Fuel Filter Difference | - | 32 | 1 | 1 | bar | 100000 |
| | LM LO P-Lube Oil aft. Filter (ECU) | - | 32 | 5 | 1 | bar | 100000 |
| 556 | LM LOLO P-Lube Oil aft. Filter (ECU) | - | 32 | 1 | 1 | bar | 100000 |
| | LM HI P-Lube Oil Filter Diff. | - | 32 | 5 | 1 | bar | 100000 |
| 557 | LM LO P-Lube Oil A-Side ETCs | - | 32 | 1 | 1 | bar | 100000 |
| | LM LO P-Lube Oil B-Side ETCs | - | 32 | 5 | 1 | bar | 100000 |
| 558 | LM LOLO P-Lube Oil A-Side ETCs | - | 32 | 1 | 1 | bar | 100000 |
| | LM LOLO P-Lube Oil B-Side ETCs | - | 32 | 5 | 1 | bar | 100000 |
| 559 | LM LO P-Oil Re-Fill Pump | - | 32 | 1 | 1 | bar | 100000 |
| | LM LO P-Lube Oil aft. Filter SaSy | - | 32 | 5 | 1 | bar | 100000 |
| 560 | LM LOLO P-Lube Oil aft. Filter SaSy | - | 32 | 1 | 1 | bar | 100000 |
| | LM HI P-Exhaust Diff SCR | - | 32 | 5 | 1 | bar | 100000 |
| 561 | LM HIHI P-Exhaust Diff SCR | - | 32 | 1 | 1 | bar | 100000 |
| | LM LO P-RA Filter Out At PFM | - | 32 | 5 | 1 | bar | 100000 |
| 562 | LM LO P-Fuel Prefilter | - | 32 | 1 | 1 | bar | 100000 |
| | LM LOLO P-Fuel Prefilter | - | 32 | 5 | 1 | bar | 100000 |
| 563 | LM HI P-Crankcase | - | 32 | 1 | 1 | mbar | 100 |
| | LM HIHI P-Crankcase | - | 32 | 5 | 1 | mbar | 100 |
| 564 | LM HI T-Intake Air | - | 32 | 1 | 1 | degC | 100 |
| | LM LO T-Exhaust | - | 32 | 5 | 1 | degC | 100 |