Gas Generator Sets
Power Generation - Gas Engines Series 4000

Gas Type	Natural Gas
Application group	**Continuous Power (COP) - 3A**
Mode of operation	Continuous operation
Load factor	≤100% constant load according to ISO 8528
Operating hours	Unlimited hours
Exhaust emissions	NO_x, stated as NO_2 (dry, 5% O_2) mg/m^3 i.N. <500 / NO_x250 on request

400 V					
Sales Name	**Engine Type**	**kW_{el}**	**Electrical Efficiency**	**Methane No.**	**Air Intake / LT Inlet Temp. °C**
MTU 8V4000 GS	L32	776	41,9%	≥ 80	35 / 53
MTU 12V4000 GS	L32	1.169	42,6%	≥ 80	35 / 53
MTU 16V4000 GS	L32 ER	1.560	40,5%	≥ 60	35 / 53
MTU 16V4000 GS	L32	1.560	42,7%	≥ 80	35 / 53
MTU 16V4000 GS*	L32 ER	1.714	40,7%	≥ 66	35 / 53
MTU 20V4000 GS	L32 ER	1.948	40,5%	≥ 60	35 / 53
MTU 20V4000 GS	L32	1.948	42,6%	≥ 80	35 / 53
MTU 20V4000 GS	L32 ER	2.145	40,8%	≥ 66	35 / 53
MTU 8V4000 GS*	L33	776	42,4%	≥ 70	25 / 40
MTU 12V4000 GS*	L33	1.169	42,8%	≥ 70	25 / 40
MTU 16V4000 GS*	L33	1.560	42,8%	≥ 70	25 / 40
MTU 20V4000 GS	L33	1.948	42,7%	≥ 70	25 / 40
MTU 20V4000 GS*	L33	1.950	42,8%	≥ 70	25 / 40
MTU 20V4000 GS*	L33	1.999	42,8%	≥ 75	25 / 40
MTU 8V4000 GS*	L33	854	42,8%	≥ 80	25 / 40
MTU 12V4000 GS	L33	1.286	43,2%	≥ 80	25 / 40
MTU 12V4000 GS*	L33	1.287	43,3%	≥ 80	25 / 40
MTU 16V4000 GS*	L33	1.714	42,9%	≥ 80	25 / 40
MTU 20V4000 GS*	L33	2.145	43,0%	≥ 80	25 / 40

* Grid Guideline BDEW compliant

Reference conditions	**Standard**
Intake air temperature	25 / 35 °C
Relative air humidity	30%
Site altitude above sea level	100 m

Gas Generator Sets
Power Generation - Gas Engines Series 4000

Gas Type	Natural Gas
Application group	**Continuous Power (COP) - 3A**
Mode of operation	Continuous operation
Load factor	≤100% constant load according to ISO 8528
Operating hours	Unlimited hours
Exhaust emissions	NO_x, stated as NO_2 (dry, 5% O_2) mg/m^3 i.N. <500 / NO_x250 on request

400 V					
Sales Name	**Engine Type**	**kW_{el}**	**Electrical Efficiency**	**Methane No.**	**Air Intake / LT Inlet Temp. °C**
MTU 8V4000 GS*	L64	854	43,4%	≥ 70	25 / 43
MTU 8V4000 GS*	L64	1.013	44,0%	≥ 80	25 / 43
MTU 12V4000 GS	L64	1.286	43,8%	≥ 70	25 / 43
MTU 12V4000 GS*	L64	1.521	44,2%	≥ 80	25 / 43
MTU 16V4000 GS*	L64	1.714	43,8%	≥ 70	25 / 43
MTU 16V4000 GS*	L64	1.999	44,3%	≥ 80	25 / 43
MTU 16V4000 GS*	L64	2.028	44,3%	≥ 80	25 / 43
MTU 16V4000 GS*	L64FNER	2,028	43,6%	≥ 72	25 / 43
MTU 16V4000 GS*	L64FNER	2,028	43,4%	≥ 80	35 / 58
MTU 20V4000 GS*	L64	2.145	43,6%	≥ 70	25 / 43
MTU 20V4000 GS*	L64	2.535	44,1%	≥ 80	25 / 43

415 V					
Sales Name	**Engine Type**	**kW_{el}**	**Electrical Efficiency**	**Methane No.**	**Air Intake / LT Inlet Temp. °C**
MTU 16V4000 GS	L32 ER	1.560	40,5%	≥ 60	35 / 53
MTU 16V4000 GS*	L32 ER	1.714	40,7%	≥ 66	35 / 53
MTU 16V4000 GS*	L64FNER	2,028	43,4%	≥ 80	35 / 58
MTU 20V4000 GS	L32 ER	1.950	40,5%	≥ 60	35 / 53
MTU 20V4000 GS	L32 ER	2.145	40,8%	≥ 66	35 / 53

* Grid Guideline BDEW compliant

Reference conditions	**Standard**
Intake air temperature	25 / 35 °C
Relative air humidity	30%
Site altitude above sea level	100 m

Gas Generator Sets
Power Generation - Gas Engines Series 4000

Gas Type	Natural Gas
Application group	**Continuous Power (COP) - 3A**
Mode of operation	Continuous operation
Load factor	≤100% constant load according to ISO 8528
Operating hours	Unlimited hours
Exhaust emissions	NO_x, stated as NO_2 (dry, 5% O_2) mg/m^3 i.N. <500 / NO_x250 on request

6,3 kV					
Sales Name	**Engine Type**	**kW_{el}**	**Electrical Efficiency**	**Methane No.**	**Air Intake / LT Inlet Temp. °C**
MTU 12V4000 GS	L32	1.166	42,4%	≥ 80	35 / 53
MTU 16V4000 GS	L32 ER	1.557	40,5%	≥ 60	35 / 53
MTU 16V4000 GS	L32	1.557	42,6%	≥ 80	35 / 53
MTU 16V4000 GS	L32 ER	1.712	40,7%	≥ 66	35 / 53
MTU 20V4000 GS	L32 ER	1.950	40,5%	≥ 60	35 / 53
MTU 20V4000 GS	L32	1.950	42,6%	≥ 80	35 / 53
MTU 20V4000 GS	L32 ER	2.145	40,8%	≥ 66	35 / 53
MTU 16V4000 GS*	L33	1.557	42,7%	≥ 70	25 / 40
MTU 20V4000 GS*	L33	1.948	42,7%	≥ 70	25 / 40
MTU 20V4000 GS	L33	1.950	42,8%	≥ 70	25 / 40
MTU 20V4000 GS*	L33	1.999	42,8%	≥ 75	25 / 40
MTU 12V4000 GS	L33	1.284	43,2%	≥ 80	25 / 40
MTU 16V4000 GS	L33	1.712	42,9%	≥ 80	25 / 40
MTU 16V4000 GS*	L33	1.716	43,0%	≥ 80	25 / 40
MTU 20V4000 GS	L33	2.145	43,0%	≥ 80	25 / 40
MTU 20V4000 GS*	L33	2.145	43,0%	≥ 80	25 / 40

* Grid Guideline BDEW compliant

Reference conditions	**Standard**
Intake air temperature	25 / 35 °C
Relative air humidity	30%
Site altitude above sea level	100 m

Gas Generator Sets
Power Generation - Gas Engines Series 4000

Gas Type	Natural Gas
Application group	**Continuous Power (COP) - 3A**
Mode of operation	Continuous operation
Load factor	≤100% constant load according to ISO 8528
Operating hours	Unlimited hours
Exhaust emissions	NO_x, stated as NO_2 (dry, 5% O_2) mg/m^3 i.N. <500 / NO_x250 on request

6,3 kV					
MTU 12V4000 GS*	L64	1.284	43,8%	≥ 70	25 / 43
MTU 12V4000 GS*	L64	1.518	44,1%	≥ 80	25 / 43
MTU 16V4000 GS	L64	1.712	43,8%	≥ 70	25 / 43
MTU 16V4000 GS*	L64	1.999	44,3%	≥ 80	25 / 43
MTU 16V4000 GS*	L64	2.028	44,3%	≥ 80	25 / 43
MTU 16V4000 GS*	L64FNER	2,028	43,6%	≥ 72	25 / 43
MTU 16V4000 GS*	L64FNER	2,028	43,4%	≥ 80	35 / 58
MTU 20V4000 GS*	L64	2.145	43,6%	≥ 70	25 / 43
MTU 20V4000 GS*	L64	2.540	44,2%	≥ 80	25 / 43

* Grid Guideline BDEW compliant

Reference conditions	**Standard**
Intake air temperature	25 / 35 °C
Relative air humidity	30%
Site altitude above sea level	100 m