Aenderungsbeschreibung/Description of Revision	Kommt vor/Frequency
war kZ	

Buchst./Rev.Ltr.	Aenderungs-Nr./Revision Notice No.	Bearbeitungsstatus/Lifecycle
-.7	PR063865	Released

Changes from Var1 Ed 01.02 to Var1 Ed 01.04
Corrections:
CAID 901, 902 deleted
New measuring points added:
CANID 419, 420, 440, 441, 442 added
New limits added:
CAID 606, 607, 608, 609, 610, 611 added
New alarms added:

AL Wiring Emergency Stop SaSy
LOLO T-ExhaustA1
LOLO T-ExhaustA2
LOLO T-ExhaustA3
LOLO T-ExhaustA4
LOLO T-ExhaustA5
LOLO T-ExhaustA6
LOLO T-ExhaustA7
LOLO T-ExhaustA8
LOLO T-ExhaustA9
LOLO T-ExhaustA10
LOLO T-ExhaustB1
LOLO T-ExhaustB2
LOLO T-ExhaustB3
LOLO T-ExhaustB4
LOLO T-ExhaustB5
LOLO T-ExhaustB6
LOLO T-ExhaustB7
LOLO T-ExhaustB8
LOLO T-ExhaustB9
LOLO T-ExhaustB10
HIHI T ExhaustA1
HIHI T ExhaustA2
HIHI T ExhaustA3
HIHI T ExhaustA4
HIHI T ExhaustA5
HIHI T ExhaustA6
HIHI T ExhaustA7
HIHI T ExhaustA8
HIHI T ExhaustA9
HIHI T ExhaustA10
HIHI T ExhaustB1
HIHI T ExhaustB2
HIHI T ExhaustB3
HIHI T ExhaustB4
HIHI T ExhaustB5
HIHI T ExhaustB6

Tolerierung/Tolerancing ISO 8015 | Masse/Size ISO 14405

Allgemeintoleranzen/General Tolerances ISO 2768-mK

Masse/Mass kg | Format/Size **A4**

Bauart/Type: Genoline | NewGeneration

Ausf. u.Lieferung Tech. Characteristics

Allgemeine Fertigungsvorschriften nach MMN332
Production Specification per MMN 332

Werkstoff/Material

Oberflaechenschutz Surface Protection

Oberflaechenangaben nach MTN5033
Surface Specification per MTN5033

Halbzeug,Modell Gesenk / Semifinished Product Pattern, Die

Verwendbar fuer Typ/Applicable to Model: GLNG Release 20

Projekt-/Auftrags-Nr./Project/Order No.

Fert.Ber. Man.Adv

Mont.Ber. Inst.Adv

Material-Nr./Material No.

Ref.-Nr./Ref. No. Type1 Var01 ED01_02 | Emission ID

XZ00E52000022

WORD	Datum/Date	Name
Erstell. Drawn	2019-08-22 10:06:33	schaepers
Bearb. Change	2020-11-05 13:42:23	kellerma
Norm Std.		ihmor stef
Gepr. Checked		ihmor stef

Benennung/ Title /

DOKUMENTATION
GLNG Fremdschnittstelle CANopen
DOCUMENTATION
GLNG Foreign MCS CANopen

Zeichnungs-Nr./Drawing No. ZNG00026575

Beschreibung/Description Type1 Var01 ED01_04

Blatt/ Sheet 1 von/of 37

T-468-0107

Aenderungsbeschreibung/Description of Revision		Kommt vor/Frequency
war kZ		
Buchst./Rev.Ltr. -.7	Aenderungs-Nr./Revision Notice No. PR063865	Bearbeitungsstatus/Lifecycle Released

HIHI T ExhaustB7
HIHI T ExhaustB8
HIHI T ExhaustB9
HIHI T ExhaustB10
AL_EmissionComplianceFailure
SD_P_ExhaustDiffSCR1
AL_ComLostAmmoniaNH3_SCR_Out1
SD_AmmoniaNH3_SCR_Out1
HI_P_ExhaustSCRInlet1
HIHI_P_ExhaustSCRInlet1
HIHIHI_P_ExhaustSCRInlet1
HI_P_ExhaustSCRInlet2
HIHI_P_ExhaustSCRInlet2
HI_SCR_HC1_Deposition
HIHI_SCR_HC1_Deposition
HIHIHI_SCR_HC1_Deposition
HI_SCR_HC2_Deposition
HIHI_SCR_HC2_Deposition
HIHIHI_SCR_HC2_Deposition
HI_SCR_RADeposition
HIHI_SCR_RADeposition
HI_AmmoniaNH3_SCR_Out1
HIHI_AmmoniaNH3_SCR_Out1
HIHIHI_AmmoniaNH3_SCR_Out1
AL_ComLostAmmoniaNH3_SCR_Out2
SD_AmmoniaNH3_SCR_Out2
HI_AmmoniaNH3_SCR_Out2
HIHI_AmmoniaNH3_SCR_Out2
HIHIHI_AmmoniaNH3_SCR_Out2
LO_T_ReducingAgentSUDU_F1
LO_P_ReducingAgentDU_F1
HI_P_ReducingAgentDU_F1
HI_Exhaust_NOx
AL_ElectricalFault_VND
AL_ElectricalFault_VNC
AL_HydraulicsFault_VND
AL_HydraulicsFault_VNR
AL_RA_SupplyUnitDefectSU1
AL_RA_SupplyUnitDefectSU2
AL_RA_SupplyUnitDefectSU3
AL_RA_SupplyUnitDefectSU4
AL_RA_SupplyUnitDefectSU5
AL_RA_SupplyUnitDefectSU6
SD_P_FuelBefAddSecFilter
AL Injector Defect_A1
AL Injector Defect_A2
AL Injector Defect_A3
AL Injector Defect_A4
AL Injector Defect_A5
AL Injector Defect_A6
AL Injector Defect_A7
AL Injector Defect_A8
AL Injector Defect_A9
AL Injector Defect_A10
AL Injector Defect_B1
AL Injector Defect_B2
AL Injector Defect_B3
AL Injector Defect_B4
AL Injector Defect_B5
AL Injector Defect_B6
AL Injector Defect_B7
AL Injector Defect_B8
AL Injector Defect_B9
AL Injector Defect_B10
AL Injector Defect critical_A1
AL Injector Defect critical_A2
AL Injector Defect critical_A3
AL Injector Defect critical_A4
AL Injector Defect critical_A5
AL Injector Defect critical_A6
AL Injector Defect critical_A7
AL Injector Defect critical_A8
AL Injector Defect critical_A9
AL Injector Defect critical_A10
AL Injector Defect critical_B1
AL Injector Defect critical_B2
AL Injector Defect critical_B3
AL Injector Defect critical_B4
AL Injector Defect critical_B5
AL Injector Defect critical_B6
AL Injector Defect critical_B7
AL Injector Defect critical_B8
AL Injector Defect critical_B9
AL Injector Defect critical_B10
LO_P_ReducingAgent_PFM
HI_P_ReducingAgent_PFM
SD P-Exhaust Diff. SCR 2
SD P-Exhaust SCR Inlet 2
SD P-Exhaust SCR Outlet 2
HI P-Start Air
HIHI P-Start Air

PDO Mapping MTU transmit

PDO Name	CANID	Source Node	Transfer Mode	Repetition Rate	Send On Change Time	Frame Type	DLC
Digital Measuring Points 1	400	0	1	50	0	0	8
Digital Measuring Points 2	401	0	1	500	0	0	8
Digital Measuring Points 3	402	0	1	500	0	0	8
Digital Measuring Points 4	403	0	1	500	0	0	8
Digital Measuring Points 5	404	0	1	500	0	0	8
Digital Measuring Points 6	405	0	1	500	0	0	8
Digital Measuring Points 7	406	0	1	500	0	0	8
Digital Measuring Points 8	407	0	1	500	0	0	8
Digital Measuring Points 9	408	0	1	500	0	0	8
Digital Measuring Points 10	409	0	1	500	0	0	8
Digital Measuring Points 11	410	0	1	500	0	0	8
Digital Measuring Points 12	411	0	1	500	0	0	8
Digital Measuring Points 13	412	0	1	500	0	0	8
Digital Measuring Points 14	413	0	1	500	0	0	8
Digital Measuring Points 15	414	0	1	500	0	0	8
Digital Measuring Points 16	415	0	1	500	0	0	8
Digital Measuring Points 17	416	0	1	500	0	0	8
Digital Measuring Points 18	417	0	1	500	0	0	8
Digital Measuring Points 19	418	0	1	500	0	0	8
Digital Measuring Points 20	419	0	1	500	0	0	8
Digital Measuring Points 21	420	0	1	500	0	0	8
Pressure Measuring Points 1	430	0	1	500	0	0	8
Pressure Measuring Points 2	431	0	1	500	0	0	8
Pressure Measuring Points 3	432	0	1	500	0	0	8
Pressure Measuring Points 4	433	0	1	500	0	0	8
Pressure Measuring Points 5	434	0	1	500	0	0	8
Pressure Measuring Points 6	435	0	1	500	0	0	8
Pressure Measuring Points 7	436	0	1	500	0	0	8
Pressure Measuring Points 8	437	0	1	500	0	0	8
Pressure Measuring Points 9	438	0	1	500	0	0	8
Pressure Measuring Points 10	439	0	1	500	0	0	8
Pressure Measuring Points 11	440	0	1	500	0	0	8
Pressure Measuring Points 12	441	0	1	500	0	0	8
Pressure Measuring Points 13	442	0	1	500	0	0	8
Temperature Measuring Points 1	500	0	1	500	0	0	8
Temperature Measuring Points 2	501	0	1	500	0	0	8
Temperature Measuring Points 3	502	0	1	500	0	0	8
Temperature Measuring Points 4	503	0	1	500	0	0	8
Temperature Measuring Points 5	504	0	1	500	0	0	8
Temperature Measuring Points 6	505	0	1	500	0	0	8
Temperature Measuring Points 7	506	0	1	500	0	0	8
Temperature Measuring Points 8	507	0	1	500	0	0	8
Temperature Measuring Points 9	508	0	1	500	0	0	8
Temperature Measuring Points 10	509	0	1	500	0	0	8
Temperature Measuring Points 11	510	0	1	500	0	0	8
Temperature Measuring Points 12	511	0	1	500	0	0	8
Temperature Measuring Points 13	512	0	1	500	0	0	8
Temperature Measuring Points 14	513	0	1	500	0	0	8
Temperature Measuring Points 15	514	0	1	500	0	0	8
Temperature Measuring Points 16	515	0	1	500	0	0	8
Temperature Measuring Points 17	516	0	1	500	0	0	8
Temperature Measuring Points 18	517	0	1	500	0	0	8
Temperature Measuring Points 19	518	0	1	500	0	0	8
Temperature Measuring Points 20	519	0	1	500	0	0	8
Temperature Measuring Points 21	520	0	1	500	0	0	8
Temperature Measuring Points 22	521	0	1	500	0	0	8
Temperature Measuring Points 23	522	0	1	500	0	0	8
Temperature Measuring Points 24	523	0	1	500	0	0	8
Temperature Measuring Points 25	524	0	1	500	0	0	8
Temperature Measuring Points 26	525	0	1	500	0	0	8

Aenderungsbeschreibung/Description of Revision

war kZ

Kommt vor/Frequency

Buchst./Rev.Ltr. -.7

Aenderungs-Nr./Revision Notice No. PR063865

Bearbeitungsstatus/Lifecycle Released

PDO Name	CANID	Source Node	Transfer Mode	Repetition Rate	Send On Change Time	Frame Type	DLC
Temperature Measuring Points 27	526	0	1	500	0	0	8
Temperature Measuring Points 28	527	0	1	500	0	0	8
Temperature Measuring Points 29	528	0	1	500	0	0	8
Temperature Measuring Points 30	529	0	1	500	0	0	8
Temperature Measuring Points 31	530	0	1	500	0	0	8
Temperature Measuring Points 32	531	0	1	500	0	0	8
Temperature Measuring Points 33	532	0	1	500	0	0	8
Temperature Measuring Points 34	533	0	1	500	0	0	8
Temperature Measuring Points 35	534	0	1	500	0	0	8
Measuring Point Limits 1	550	0	1	500	0	0	8
Measuring Point Limits 2	551	0	1	500	0	0	8
Measuring Point Limits 3	552	0	1	500	0	0	8
Measuring Point Limits 4	553	0	1	500	0	0	8
Measuring Point Limits 5	554	0	1	500	0	0	8
Measuring Point Limits 6	555	0	1	500	0	0	8
Measuring Point Limits 7	556	0	1	500	0	0	8
Measuring Point Limits 8	557	0	1	500	0	0	8
Measuring Point Limits 9	558	0	1	500	0	0	8
Measuring Point Limits 10	559	0	1	500	0	0	8
Measuring Point Limits 11	560	0	1	500	0	0	8
Measuring Point Limits 12	561	0	1	500	0	0	8
Measuring Point Limits 13	562	0	1	500	0	0	8
Measuring Point Limits 14	563	0	1	500	0	0	8
Measuring Point Limits 15	564	0	1	500	0	0	8
Measuring Point Limits 16	565	0	1	500	0	0	8
Measuring Point Limits 17	566	0	1	500	0	0	8
Measuring Point Limits 18	567	0	1	500	0	0	8
Measuring Point Limits 19	568	0	1	500	0	0	8
Measuring Point Limits 20	569	0	1	500	0	0	8
Measuring Point Limits 21	570	0	1	500	0	0	8
Measuring Point Limits 22	571	0	1	500	0	0	8
Measuring Point Limits 23	572	0	1	500	0	0	8
Measuring Point Limits 24	573	0	1	500	0	0	8
Measuring Point Limits 25	574	0	1	500	0	0	8
Measuring Point Limits 26	575	0	1	500	0	0	8
Measuring Point Limits 27	576	0	1	500	0	0	8
Measuring Point Limits 28	577	0	1	500	0	0	8
Measuring Point Limits 29	578	0	1	500	0	0	8
Measuring Point Limits 30	579	0	1	500	0	0	8
Measuring Point Limits 31	580	0	1	500	0	0	8
Measuring Point Limits 32	581	0	1	500	0	0	8
Measuring Point Limits 33	582	0	1	500	0	0	8
Measuring Point Limits 34	583	0	1	500	0	0	8
Measuring Point Limits 35	584	0	1	500	0	0	8
Measuring Point Limits 36	585	0	1	500	0	0	8
Measuring Point Limits 37	586	0	1	500	0	0	8
Measuring Point Limits 38	587	0	1	500	0	0	8
Measuring Point Limits 39	588	0	1	500	0	0	8
Measuring Point Limits 40	589	0	1	500	0	0	8
Measuring Point Limits 41	590	0	1	500	0	0	8
Measuring Point Limits 42	591	0	1	500	0	0	8
Measuring Point Limits 43	592	0	1	500	0	0	8
Measuring Point Limits 44	593	0	1	500	0	0	8
Measuring Point Limits 45	594	0	1	500	0	0	8
Measuring Point Limits 46	595	0	1	500	0	0	8
Measuring Point Limits 47	596	0	1	500	0	0	8
Measuring Point Limits 48	597	0	1	500	0	0	8
Measuring Point Limits 49	598	0	1	500	0	0	8
Measuring Point Limits 50	599	0	1	500	0	0	8
Measuring Point Limits 51	600	0	1	500	0	0	8
Measuring Point Limits 52	601	0	1	500	0	0	8
Measuring Point Limits 53	602	0	1	500	0	0	8
Measuring Point Limits 54	603	0	1	500	0	0	8
Measuring Point Limits 55	604	0	1	500	0	0	8

Aenderungsbeschreibung/Description of Revision	Kommt vor/Frequency
war kZ	

Buchst./Rev.Ltr.	Aenderungs-Nr./Revision Notice No.	Bearbeitungsstatus/Lifecycle
-.7	PR063865	Released

PDO Name	CANID	Source Node	Transfer Mode	Repetition Rate	Send On Change Time	Frame Type	DLC
Measuring Point Limits 56	605	0	1	500	0	0	8
Measuring Point Limits 57	606	0	1	500	0	0	8
Measuring Point Limits 58	607	0	1	500	0	0	8
Measuring Point Limits 59	608	0	1	500	0	0	8
Measuring Point Limits 60	609	0	1	500	0	0	8
Measuring Point Limits 61	610	0	1	500	0	0	8
Measuring Point Limits 62	611	0	1	500	0	0	8
Binary Measuring Points 1	700	0	1	500	0	0	8
Binary Alarms 1	701	0	1	500	0	0	8
Binary Alarms 2	702	0	1	500	0	0	8
Binary Alarms 3	703	0	1	500	0	0	8
Binary Alarms 4	704	0	1	500	0	0	8
Binary Alarms 5	705	0	1	500	0	0	8
Binary Alarms 6	706	0	1	500	0	0	8
Binary Alarms 7	707	0	1	500	0	0	8
Binary Alarms 8	708	0	1	500	0	0	8
Binary Alarms 9	709	0	1	500	0	0	8
Binary Alarms 10	710	0	1	500	0	0	8
Binary Alarms 11	711	0	1	500	0	0	8
Binary Alarms 12	712	0	1	500	0	0	8
Binary Alarms 13	713	0	1	500	0	0	8
Binary Alarms 14	714	0	1	500	0	0	8
Binary Alarms 15	715	0	1	500	0	0	8
Binary Alarms 16	716	0	1	500	0	0	8
Binary Alarms 17	717	0	1	500	0	0	8
Binary Alarms 18	718	0	1	500	0	0	8

Signal range and interpretation of MTU transmit data

Non binary signals	
Bitsize	32
CANID	400-605
Valid range	0-FAFFFFFFh (-2105540607.5 up to 2105540607.5) Offset: 2105540607
Sensor defect SD	FEFFFFFFh
Missing data MD	FFFFFFFFh

Binary signals		
Bitsize	2	
CANID	700	
-	Bit1	Bit0
Inactive	0	0
Active	0	1
Sensor defect SD	1	0
Missing data MD	1	1

Alarms		
Bitsize	2	
CANID	701-721	
-	Bit1	Bit0
Alarm inactive	*Ignore*	0
Alarm active	*ignore*	1

Example of „Engine Speed“:

- actual engine speed: 2890,4 rpm
- CAN raw value: 0x7D8070E7 (=2105569511)
- calculated value less offset: 2105569511-2105540607 = 28904
- divided by rpm scaling factor 10: 2890,4 rpm

CANID Mapping MTU transmit

CANID	Signal Name	Alarm Description	Bitsize	Startbyte	Startbit	Unit	Scaling
400	Engine Speed	-	32	1	1	rpm	10
	Idle Speed	-	32	5	1	rpm	10
401	Nominal Speed	-	32	1	1	rpm	10
	Feedback Speed Demand	-	32	5	1	rpm	10
402	Feedback Speed Demand Eff.	-	32	1	1	rpm	10
	Injection in Relation to DBR	-	32	5	1	%	1000
403	Injection Limitation 0-120%	-	32	1	1	%	1000
	Trip Fuel Consumption HI	-	32	5	1	l	10
404	Mean Trip Fuel Consumption	-	32	1	1	l/h	1000
	Trip Duration HI	-	32	5	1	h	1
405	Actual Fuel Consumption	-	32	1	1	l/h	1000
	Total Fuel Consumption HI	-	32	5	1	l	10
406	Fuel Consumpt Max lh DIS	-	32	1	1	l/h	1000
	Fuel Consumpt Act DIS	-	32	5	1	%	1000
407	Fuel Cons Mean Trip DIS	-	32	1	1	%	1000
	Status Start Procedure	-	32	5	1	digit	1
408	Power Supply EIM/Starter Bat.	-	32	1	1	V	1000
	ECU Power Supply Voltage	-	32	5	1	V	1000
409	ETC 1 Speed	-	32	1	1	krpm	10000
	ETC 2 Speed	-	32	5	1	krpm	10000
410	ETC 3 Speed	-	32	1	1	krpm	10000
	ETC 4 Speed	-	32	5	1	krpm	10000
411	ECU Operat.Hours	-	32	1	1	sec	1
	ECU Failure Codes	-	32	5	1	digit	1
412	Engine Speed SaSy	-	32	1	1	rpm	10
	RA Tank Level Norm	-	32	5	1	%	1000
413	UserInstruction	-	32	1	1	digit	1
	UTC Seconds	-	32	5	1	digit	1
414	UTC Minutes	-	32	1	1	digit	1
	UTC Hour	-	32	5	1	digit	1
415	Day	-	32	1	1	digit	1
	Month	-	32	5	1	digit	1
416	Year	-	32	1	1	digit	1
	Alarmmanagement Group Static	-	32	5	1	digit	1
417	Alarmmanagement Group Dynamic	-	32	1	1	digit	1
	Power Actual Gen	-	32	5	1	kW	1000
418	Engine Load Reserve	-	32	1	1	%	1000
	Injection Quantity 0-120	-	32	5	1	%	1000

CANID	Signal Name	Alarm Description	Bitsize	Startbyte	Startbit	Unit	Scaling
419	RA Concentration	-	32	1	1	%	1000
	SCR System State	-	32	5	1	digit	1
420	ActualRAConsumption_ECU	-	32	1	1	l/h	1000
430	P-Start Air	-	32	1	1	bar	100000
	P-Charge Air A	-	32	5	1	bar	100000
431	P-Crankcase	-	32	1	1	mbar	100
	P-Coolant	-	32	5	1	bar	100000
432	P-Raw Water	-	32	1	1	bar	100000
	P-Fuel	-	32	5	1	bar	100000
433	P-Fuel before Filter (ECU)	-	32	1	1	bar	100000
	P-Fuel Filter Difference	-	32	5	1	bar	100000
434	P-Fuel Prefilter Diff.	-	32	1	1	bar	100000
	P-Lube Oil aft. Filter (ECU)	-	32	5	1	bar	100000
435	P-Lube Oil before Filter (ECU)	-	32	1	1	bar	100000
	P-Oil Filter Difference	-	32	5	1	bar	100000
436	P-Lube Oil A-Side ETCs	-	32	1	1	bar	100000
	P-Lube Oil B-Side ETCs	-	32	5	1	bar	100000
437	P-Oil Refill Pump	-	32	1	1	bar	100000
	P-Lube Oil aft. Filter SaSy	-	32	5	1	bar	100000
438	P-Exhaust Diff SCR1	-	32	1	1	bar	100000
	P-RA Filter Out At PFM	-	32	5	1	bar	100000
439	P-Fuel Prefilter	-	32	1	1	bar	100000
	P-Exhaust Back	-	32	5	1	mbar	100
440	P-Exhaust SCR Inlet1	-	32	1	1	bar	100000
	P-Exhaust SCR Inlet2	-	32	5	1	bar	100000
441	P-Exhaust Diff SCR2	-	32	1	1	bar	100000
	P-Dosing Air SUDU 1	-	32	5	1	bar	100000
442	P-Exhaust SCR Inlet 1 redundant	-	32	1	1	bar	100000
500	T-Intake Air	-	32	1	1	degC	100
	T-Exhaust A1	-	32	5	1	degC	100
501	T-Exhaust A2	-	32	1	1	degC	100
	T-Exhaust A3	-	32	5	1	degC	100
502	T-Exhaust A4	-	32	1	1	degC	100
	T-Exhaust A5	-	32	5	1	degC	100
503	T-Exhaust A6	-	32	1	1	degC	100
	T-Exhaust A7	-	32	5	1	degC	100
504	T-Exhaust A8	-	32	1	1	degC	100
	T-Exhaust A9	-	32	5	1	degC	100
505	T-Exhaust A10	-	32	1	1	degC	100
	T-Exhaust B1	-	32	5	1	degC	100

CANID	Signal Name	Alarm Description	Bitsize	Startbyte	Startbit	Unit	Scaling
506	T-Exhaust B2	-	32	1	1	degC	100
	T-Exhaust B3	-	32	5	1	degC	100
507	T-Exhaust B4	-	32	1	1	degC	100
	T-Exhaust B5	-	32	5	1	degC	100
508	T-Exhaust B6	-	32	1	1	degC	100
	T-Exhaust B7	-	32	5	1	degC	100
509	T-Exhaust B8	-	32	1	1	degC	100
	T-Exhaust B9	-	32	5	1	degC	100
510	T-Exhaust B10	-	32	1	1	degC	100
	T-Exhaust Mean	-	32	5	1	degC	100
511	T-Exhaust Combined A	-	32	1	1	degC	100
	T-Exhaust before ETC (Combined B)	-	32	5	1	degC	100
512	T-Exhaust Combined C	-	32	1	1	degC	100
	T-Exhaust Combined D	-	32	5	1	degC	100
513	T-Charge Air A	-	32	1	1	degC	100
	T-Charge Air Seq Ctrl Valve	-	32	5	1	degC	100
514	T-Coolant (ECU)	-	32	1	1	degC	100
	T-Fuel Common Rail A	-	32	5	1	degC	100
515	T-Lube Oil	-	32	1	1	degC	100
	T-Lube Oil ETC	-	32	5	1	degC	100
516	T-Splash Oil B1	-	32	1	1	degC	100
	T-Splash Oil B2	-	32	5	1	degC	100
517	T-Splash Oil B3	-	32	1	1	degC	100
	T-Splash Oil B4	-	32	5	1	degC	100
518	T-Splash Oil B5	-	32	1	1	degC	100
	T-Splash Oil B6	-	32	5	1	degC	100
519	T-Splash Oil B7	-	32	1	1	degC	100
	T-Splash Oil B8	-	32	5	1	degC	100
520	T-Splash Oil B9	-	32	1	1	degC	100
	T-Splash Oil B10	-	32	5	1	degC	100
521	T-Bearing 1	-	32	1	1	degC	100
	T-Bearing 2	-	32	5	1	degC	100
522	T-Bearing 3	-	32	1	1	degC	100
	T-Bearing 4	-	32	5	1	degC	100
523	T-Bearing 5	-	32	1	1	degC	100
	T-Bearing 6	-	32	5	1	degC	100
524	T-Bearing 7	-	32	1	1	degC	100
	T-Bearing 8	-	32	5	1	degC	100
525	T-Bearing 9	-	32	1	1	degC	100
	T-Bearing 10	-	32	5	1	degC	100

CANID	Signal Name	Alarm Description	Bitsize	Startbyte	Startbit	Unit	Scaling
526	T-Bearing 11	-	32	1	1	degC	100
	T-Bearing Mean	-	32	5	1	degC	100
527	T-ECU	-	32	1	1	degC	100
	T-Coolant SaSy	-	32	5	1	degC	100
528	T-Exhaust SCR Inlet1	-	32	1	1	degC	100
	T-Exhaust SCR Inlet2	-	32	5	1	degC	100
529	T-Exhaust SCR Outlet1	-	32	1	1	degC	100
	T-Reducing Agent At PFM	-	32	5	1	degC	100
530	T-AirInlet Gen	-	32	1	1	degC	100
	T-AirOutlet Gen	-	32	5	1	degC	100
531	T-Bearing GenDE	-	32	1	1	degC	100
	T-Bearing GenNDE	-	32	5	1	degC	100
532	T-WindingL1 Gen	-	32	1	1	degC	100
	T-WindingL2 Gen	-	32	5	1	degC	100
533	T-WindingL3 Gen	-	32	1	1	degC	100
	T-Coolant Gen Out	-	32	5	1	degC	100
534	T-Coolant Gen In	-	32	1	1	degC	100
	T-Splash Oil Mean	-	32	5	1	degC	100
550	LM LO RA Tank Level	-	32	1	1	%	1000
	LM LOLO RA Tank Level	-	32	5	1	%	1000
551	LM LO P-Start Air	-	32	1	1	bar	100000
	LM LOLO P-Start Air	-	32	5	1	bar	100000
552	LM HI P-Charge Air A	-	32	1	1	bar	100000
	LM LO P-Coolant	-	32	5	1	bar	100000
553	LM LOLO P-Coolant	-	32	1	1	bar	100000
	LM LO P-Raw Water	-	32	5	1	bar	100000
554	LM LO P-Fuel	-	32	1	1	bar	100000
	LM LOLO P-Fuel	-	32	5	1	bar	100000
555	LM HI P-Fuel Filter Difference	-	32	1	1	bar	100000
	LM LO P-Lube Oil aft. Filter (ECU)	-	32	5	1	bar	100000
556	LM LOLO P-Lube Oil aft. Filter (ECU)	-	32	1	1	bar	100000
	LM HI P-Lube Oil Filter Diff.	-	32	5	1	bar	100000
557	LM LO P-Lube Oil A-Side ETCs	-	32	1	1	bar	100000
	LM LO P-Lube Oil B-Side ETCs	-	32	5	1	bar	100000
558	LM LOLO P-Lube Oil A-Side ETCs	-	32	1	1	bar	100000
	LM LOLO P-Lube Oil B-Side ETCs	-	32	5	1	bar	100000
559	LM LO P-Oil Re-Fill Pump	-	32	1	1	bar	100000
	LM LO P-Lube Oil aft. Filter SaSy	-	32	5	1	bar	100000
560	LM LOLO P-Lube Oil aft. Filter SaSy	-	32	1	1	bar	100000
	LM HI P-Exhaust Diff SCR	-	32	5	1	bar	100000