



Maintenance Schedule

Diesel Engine
V 2000 Gx5
Application Group 3A

MS50001/04E

Engine model	kW/cyl.	Application group
12V2000G25	37.7 kW/cyl.	3A, continuous operation, unrestricted, ICXN
12V2000G25-TB	37.7 kW/cyl.	3A, continuous operation, unrestricted, ICXN
12V2000G65	42.9 kW/cyl.	3A, continuous operation, unrestricted, ICXN
12V2000G65-TB	42.9 kW/cyl.	3A, continuous operation, unrestricted, ICXN
16V2000G45	42.8 kW/cyl.	3A, continuous operation, unrestricted, ICXN
16V2000G45-TB	42.8 kW/cyl.	3A, continuous operation, unrestricted, ICXN
16V2000G65	40.9 kW/cyl.	3A, continuous operation, unrestricted, ICXN
16V2000G65-TB	40.9 kW/cyl.	3A, continuous operation, unrestricted, ICXN
16V2000G85	49.4 kW/cyl.	3A, continuous operation, unrestricted, ICXN
16V2000G85-TB	49.4 kW/cyl.	3A, continuous operation, unrestricted, ICXN
18V2000G65	40 kW/cyl.	3A, continuous operation, unrestricted, ICXN
18V2000G65-TB	40 kW/cyl.	3A, continuous operation, unrestricted, ICXN
18V2000G85	50 kW/cyl.	3A, continuous operation, unrestricted, ICXN
18V2000G85-TB	50 kW/cyl.	3A, continuous operation, unrestricted, ICXN

Table 1: Applicability

Rolls-Royce Solutions refers to Rolls-Royce Solutions GmbH or an affiliated company pursuant to § 15 AktG (German Stock Corporation Act) or a controlled company (joint venture), and Rolls-Royce Solutions Ruhstorf GmbH.

© Copyright Rolls-Royce Solutions

This publication is protected by copyright and may not be used in any way, whether in whole or in part, without the prior written consent of Rolls-Royce Solutions. This particularly applies to its reproduction, distribution, editing, translation, microfilming and storage and/or processing in electronic systems including databases and online services.

All information in this publication was the latest information available at the time of going to print. Rolls-Royce Solutions reserves the right to change, delete or supplement the information provided as and when required.

1 Maintenance Schedule

1.1 Preface

This manual provides instructions for your product from the manufacturer Rolls-Royce Solutions.

Maintenance concept

The maintenance system for Rolls-Royce Solutions products is based on a preventive maintenance concept. Preventive maintenance facilitates advance operational planning and ensures a high level of equipment availability. The maintenance intervals as well as the required scopes of maintenance tasks are based on operational experience and therefore to be considered as recommendations. Additional maintenance work and/or changes to the maintenance intervals may be required in the case of difficult operational and ambient conditions.

Adherence to the specified maintenance intervals is essential to maintain product safety.

The intervals according to which the maintenance tasks have to be carried out are specified as operating hours and time limits. Whichever value is reached first shall apply.

The maintenance intervals are determined and verified by the load profile. Load profiles can be evaluated by the Service Partner of Rolls-Royce Solutions. Reading out load profile data is recommended for the first time after between 500 and 1000 operating hours depending on the application concerned, or after changing the duty profile or operating area.

The individual maintenance intervals are assigned to the qualification levels QL1 to QL4.

QL1: Operational monitoring and maintenance work which does not require disassembly of the product.

QL2: Exchange of components and parts in case of repair (corrective only, not part of the maintenance schedule).

QL3: Maintenance work which requires partial disassembly of the product.

QL4: Maintenance work which requires complete disassembly of the product.

Additional notes on maintenance and preservation:

The relevant component manufacturer's instructions apply with respect to the maintenance of any components which do not appear in this maintenance schedule.

For the change intervals of fluids and lubricants, refer to the corresponding Fluids and Lubricants Specifications.

If the product is to remain out of service for a longer time period, Rolls-Royce Solutions recommends to carry out a monthly test run until engine operating temperature is reached. If the engine is scheduled to remain out of service for > 1 month, carry out engine preservation procedures in accordance with the Preservation and Represervation Specifications

The latest version of the specifications is available at <http://www.mtu-solutions.com>.