



Additional Maintenance Schedule

Diesel engine

V2000S56

V2000S96

V2000C66

V2000C66R

Only valid in combination with MS50090/xx

Application group 4B, 4D, 5B

MSE50090/04E

Engine model	kW/cyl.	Application group
12V2000S56	65 kW/cyl.	4B, Continuous operation, variable
16V2000S56	60 kW/cyl.	4B, Continuous operation, variable
12V2000S96	71 kW/cyl.	4D, Frac operation (continuous operation at low load)
16V2000S96	72 kW/cyl.	4D, Frac operation (continuous operation at low load)
12V2000C66	65 kW/cyl.	5B, Continuous operation, variable
12V2000C66R	65 kW/cyl.	5B, Continuous operation, variable
16V2000C66	60 kW/cyl.	5B, Continuous operation, variable

Table 1: Applicability

Rolls-Royce Solutions refers to Rolls-Royce Solutions GmbH or an affiliated company pursuant to § 15 AktG (German Stock Corporation Act) or a controlled company (joint venture), and Rolls-Royce Solutions Ruhstorf GmbH.

© Copyright Rolls-Royce Solutions

This publication is protected by copyright and may not be used in any way, whether in whole or in part, without the prior written consent of Rolls-Royce Solutions. This particularly applies to its reproduction, distribution, editing, translation, microfilming and storage and/or processing in electronic systems including databases and online services.

All information in this publication was the latest information available at the time of going to print. Rolls-Royce Solutions reserves the right to change, delete or supplement the information provided as and when required.

1 Additional Maintenance Schedule

1.1 Preface

This additional maintenance schedule is a supplement to the basic maintenance schedule MS50090/xx and applicable to engines certified in accordance with the U. S. emissions regulations and operated in the USA.

The following requirements must be noted and observed for these engines:

Modification or removal of mechanical or electronic components or the installation of additional components as well as the execution of calibration processes that might affect the emission characteristics of the engine are prohibited by emission regulations. Emission-related components, e.g. control units, sensors, cylinder heads, injectors and exhaust flaps can only be serviced, replaced or repaired if components approved by MTU or equivalent components are used.

Nonobservance of the maintenance specifications can result in violation of the legal specifications.

This additional maintenance schedule must be followed regardless of the given application and load profile.

Application group

4B	Continuous operation, variable
4D	Frac operation (continuous operation at low load)
5B	Continuous operation, variable