

**Diesel Engines****V956TB32****V1163TB32****Prime Power, Limited Time (Standby)****Maintenance Schedule****M050188/22E**

Rolls-Royce Solutions GmbH
Maybachplatz 1
D-88045 Friedrichshafen

www.mtu-solutions.com

Low operating and maintenance costs as well as operational reliability and availability depend on maintenance and servicing being carried out in compliance with our specifications and instructions.

The overall system, of which the engine is an integral part, must be maintained in such a way as to ensure trouble-free engine operation at all times. For this purpose always:

- ensure that sufficient fuel is available,
- ensure that the combustion air is dry and clean,
- use only dry, clean compressed air,
- use only clean, filtered raw water.

Moreover, it is essential that:

- maintenance tasks be completed by trained personnel,
- suitable tools be used,
- genuine spare parts and fluids and lubricants as per the current Fluids and Lubricants Specification be used.

Our Product Support Service will always be available should assistance be required.

Preventive maintenance instructions.

- Special care should be taken to keep the machinery plant in a clean and serviceable condition at all times to facilitate early detection of possible leaks and prevent subsequent damage.
- Protect rubber and synthetic components from oil and fuel, never treat with organic detergents. Wipe with a dry cloth only.

Maintenance Concept

The maintenance concept for mtu products is a preventive maintenance concept and features the maintenance echelons W1 to W6 as outlined below.

Preventive maintenance facilitates advance planning and ensures a high degree of equipment availability.

Main Features of Maintenance Tasks for mtu engines

- W1: Monthly test run / Operational Checks
- W2, W3 and W4: Periodic maintenance tasks to be performed during out-of-service periods without the need for engine disassembly.
- W5: This echelon requires partial engine disassembly.
- W6: Major overhaul. This echelon requires complete engine disassembly.



Maintenance Schedule

Group	D
Subgroup	000
Page	02

The time intervals according to which the W2 to W6 Maintenance Echelons and the relevant checks and tasks involved are to be completed are based on operational experience. They have been determined so as to ensure correct engine operation until the next scheduled maintenance echelon.
Specific operational conditions may require modification of the Maintenance Schedule.

NOTE:

The codes on the following pages refer to the groups and subgroups of the Task Descriptions in Group G of the Engine Operation Manual.
This Maintenance Schedule may refer to parts which are not installed on your engine, these may be disregarded.



**Application Group**

3C: Prime Power, Limited Time (Standby)

Maintenance Frequency Chart

Maintenance Echelon	W1: Monthly	X
	Operational checks	
	W2: annually	1
	Limit, operating hours	500
	W3: Limit, years	2
	Limit, operating hours	1 000
	W4: Limit, years	4
	Limit, operating hours	2 000
	W5: Limit, years	8
	Limit, operating hours	4 000
	W6: Limit, years	16
	Limit, operating hours	8 000

Maintenance Task Schedule

Code No.	One-time operations after the first 3 months, limit 50 operating hours – With a new engine or after W6 major overhaul	
G00.049	Attachments	Check tightness of securing screws and nuts
G06.101	Valve gear	Check valve clearances, adjust if necessary
G12.311	Fuel pre-filter	Clean
G12.321	Fuel duplex filter	Replace filter elements
G13.112	Engine coolant pumps	Check relief bore(s) for obstructions
G13.123	Raw water pump	Check relief bore for obstructions
G13.132	Charge air coolant pump	Check relief bore for obstructions
G14.019	Engine coolant system	Clean strainer before coolant thermostat. Check mesh for damage
G16.002	Engine oil	Take sample and analyse
G16.111	Engine oil filter	Operate filter handle several times