



System Documentation

Electronics

BlueVision | NewGeneration

System Extension Avantgarde

Functional Description

Operating Instructions

Application: Marine

E532886/01E



A Rolls-Royce
solution

Rolls-Royce Solutions refers to Rolls-Royce Solutions GmbH or an affiliated company pursuant to § 15 AktG (German Stock Corporation Act) or a controlled company (joint venture), and Rolls-Royce Solutions Ruhstorf GmbH.

© Copyright Rolls-Royce Solutions

This publication is protected by copyright and may not be used in any way, whether in whole or in part, without the prior written consent of Rolls-Royce Solutions. This particularly applies to its reproduction, distribution, editing, translation, microfilming and storage and/or processing in electronic systems including databases and online services.

All information in this publication was the latest information available at the time of going to print. Rolls-Royce Solutions reserves the right to change, delete or supplement the information provided as and when required.

Table of Contents

1	Preface			
1.1	Preface	5		
2	Safety			
2.1	Important provisions for electronic products	6		
2.2	Intended use of electronic products	7		
2.3	Personnel and organizational requirements	8		
2.4	Safety regulations for commissioning and operation of electronic products	9		
2.5	Safety regulations for assembly, maintenance, and repair work on electronic products	10		
2.6	Fire and environmental protection, consumables and auxiliary materials for electronic products	12		
2.7	Standards for warning messages in the text and highlighted information	13		
3	Functional Description			
3.1	Purpose and Structure	14		
3.1.1	System Extension Avantgarde	14		
3.1.2	System extension for the Rolls-Royce Solutions product line BlueVision_Advanced I New Generation	16		
3.1.3	Programmable Process Station (PPS)	17		
3.1.4	Monitoring Computer Unit (MCU)	23		
3.1.5	Monitor	25		
3.1.6	Trackball	27		
3.1.7	Keyboard	29		
3.1.8	Printer	31		
3.1.9	Process Visualization	33		
3.1.9.1	General Information	33		
3.1.9.1.1	Purpose	33		
3.1.9.1.2	Process visualization system - Features	35		
3.1.9.1.3	Hardware environment of the process visualization system	36		
3.1.9.1.4	Process visualization system - Interfaces	37		
3.1.9.2	Standardized Display Elements	38		
3.1.9.2.1	General	38		
3.1.9.2.2	Symbols	39		
3.1.9.2.3	Display boxes	44		
3.1.9.2.4	Input window	47		
3.1.9.2.5	Bargraphs	49		
3.1.9.2.6	Buttons	50		
3.1.9.2.7	Radio buttons	53		
3.1.9.2.8	List boxes	54		
3.1.9.2.9	Ship area symbols	55		
3.1.9.2.10	Key for communication	56		
3.1.9.3	Screen Page Layout	58		
3.1.9.3.1	Main pane	58		
3.1.9.3.2	Screen formats	59		
3.1.9.3.3	Screen page panes	60		
3.1.9.3.4	Header bar	61		
3.1.9.3.5	Navigation shortcuts	62		
3.1.9.3.6	Navigation pane	64		
3.1.9.3.7	Operating and display pane	65		
3.1.9.3.8	Alarm bar	66		
3.1.9.3.9	Button bar	67		
3.1.9.4	Types of Screen Pages and Windows	69		
3.1.9.4.1	Alarm bar	69		
3.1.9.4.2	Alarm Page	70		
3.1.9.4.3	Alarms and warnings	77		
3.1.9.4.4	Limits pages	79		
3.1.9.4.5	Dialog windows and dialog pages	81		
3.1.9.4.6	Settings	82		
3.1.9.4.7	Online Help pages	84		
3.1.9.4.8	Start page	86		
3.1.9.5	Additional Functions	87		
3.1.9.5.1	Additional Functions dialog	87		
3.1.9.5.2	Password protection	88		
3.1.9.5.3	User Page	89		
3.1.9.5.4	Parameter Dialog - General	91		
3.1.9.5.5	Parameter Dialog - Free Parameters	92		
3.1.9.5.6	Parameter Dialog - Alarm Parameter	93		
3.1.9.5.7	Parameter Dialog - Tank curve	94		
3.1.9.5.8	Parameter Dialog - Dialog Manager	96		
3.1.9.5.9	Alarm Printout	97		
3.1.9.5.10	Journal Printout	100		
3.1.9.5.11	Date and Time	102		
3.1.9.5.12	Service	103		
3.1.9.5.13	Info	104		
3.1.9.5.14	Trending (option)	105		
3.2	Technical Data	110		
3.2.1	Programmable Process Station	110		
3.2.2	Control console computer	112		
3.2.3	Monitor Screen	113		
3.2.3.1	TFT 15" Series X G2	113		
3.2.3.2	TFT 17" Series X G2	114		
3.2.3.3	TFT 19" Series X G2	115		
3.2.3.4	TFT 24" Series X G2	116		
3.2.3.5	TFT Touchscreen 15" Series X G2	117		
3.2.3.6	TFT Touchscreen 17" Series X G2	118		
3.2.3.7	TFT Touchscreen 19" Series X G2	119		
3.2.3.8	TFT Touchscreen 24" Series X G2	120		
3.2.4	Trackball	121		
3.2.5	Keyboard	122		
3.2.6	Printer	123		
4	Operating Instructions			
4.1	Operation	124		
4.1.1	Control Console Computer	124		
4.1.1.1	Switching on	124		

4.1.1.2	Restart	125	4.1.6.24	Journal page - Configuration	174
4.1.1.3	Reset / restart	126	4.1.6.25	Interval Journal Printout - Enabling/ disabling	176
4.1.1.4	MCU battery - Replacement	127	4.1.6.26	Alarm Printout	177
4.1.2	Monitor Screen	128	4.1.6.27	Engine Journal Printout	178
4.1.2.1	Switching on	128	4.1.6.28	Configurable Journal Printout	179
4.1.2.2	Navigation	129	4.1.6.29	Trend data - Display	180
4.1.2.3	Settings	130	4.1.6.30	Creating an export file and saving it on a storage medium	181
4.1.2.4	Screen display - Menu overview	132	4.1.6.31	Configuration - Trending	182
4.1.2.5	Switching off	139	4.1.6.32	Process graphic page LAN process bus	183
4.1.3	Trackball	140	4.1.6.33	Display of system fault page for individual process bus devices	184
4.1.3.1	Keys	140	4.1.6.34	Input of comment text for process bus devices	185
4.1.3.2	Trackball	141	4.1.6.35	Access to field bus pages	186
4.1.4	Keyboard	142	4.1.6.36	Process graphic page LAN field bus	187
4.1.4.1	Operation	142	4.1.6.37	Channel list and sample circuit display	188
4.1.5	Printer	143	4.1.6.38	Display of System Fault page of individual field bus devices	189
4.1.5.1	Switching on	143	4.1.6.39	Display of channel list for individual field bus devices	190
4.1.5.2	Switching off	144	4.1.6.40	Additional information about control panel PAN - Display	191
4.1.5.3	Paper - Loading	145	4.1.6.41	Comments for field bus devices - Input	192
4.1.5.4	Ink cartridge - Replacement	147	4.1.6.42	Legend display	193
4.1.6	Process Visualization	148	4.2	Operation	194
4.1.6.1	Initiating operations	148	4.2.1	Plant Control Through Process Visualization	194
4.1.6.2	Alphanumerical pages - Display	149	4.2.1.1	Process visualization system - Reset/restart	194
4.1.6.3	Handling alphanumeric pages, dialog pages and dialog windows	150	4.2.1.2	Process visualization system - Switching off	195
4.1.6.4	Alarm acknowledgment	151	4.2.1.3	Engine - Start	196
4.1.6.5	Individual alarms - Acknowledgment	153	4.2.1.4	Engine - Stop	198
4.1.6.6	Alarm control for ship area alarms	154	4.3	Troubleshooting	200
4.1.6.7	Alarm list - Filtering	156	4.3.1	Fault messages on the screen	200
4.1.6.8	Login	157	5	Appendix A	
4.1.6.9	Logging off	158	5.1	Abbreviations	224
4.1.6.10	Password change	159	5.2	Contact person/Service partner	230
4.1.6.11	Screensaver - Setting	160	6	Appendix B	
4.1.6.12	Touchscreen - Setting	161	6.1	Index	231
4.1.6.13	Unit - Setting	162			
4.1.6.14	Ship Name - Input	163			
4.1.6.15	Date and time - Setting	164			
4.1.6.16	Language - Setting (option)	165			
4.1.6.17	Screen display/style - Switching	166			
4.1.6.18	Fuel consumption display - Setting	167			
4.1.6.19	User Page - Configuration	168			
4.1.6.20	Printout - Enabling	170			
4.1.6.21	Alarm printout - Enabling	171			
4.1.6.22	Journal printout - Enabling	172			
4.1.6.23	Print Screen - Enabling	173			

1 Preface

1.1 Preface

This manual provides instructions for your product from the manufacturer Rolls-Royce Solutions.

2 Safety

2.1 Important provisions for electronic products

General

This product may pose a risk of injury or damage in the following cases:

- Incorrect use
- Operation, maintenance and repair by unqualified personnel
- Assembly, maintenance, and repair without ESD („Electro Static Discharge“) equipment and ESD work station
- Changes or modifications which are neither made nor authorized by the manufacturer
- Noncompliance with the safety instructions and warning notices

Nameplates

The product is identified by nameplate, model designation or serial number. This data must match the specifications in these instructions.

Nameplates, model designation or serial number can be found on the product.

2.2 Intended use of electronic products

Intended use

The product is intended for use in accordance with its contractually-defined purpose as described in the relevant technical documents only.

Intended use entails operation:

- Within the permissible operating parameters in accordance with the (→ Technical data)
- With spare parts approved by the manufacturer in accordance with the (→ Spare Parts Catalog/Rolls-Royce Solutions contact/Service partner)
- In the original configuration of the delivery or in a configuration approved in writing by the manufacturer
- In compliance with all safety regulations and in adherence with all safety and warning notices in this manual
- Work which requires communication with the control units must only be carried out with a diagnosis software or with tools approved by the manufacturer.
- In compliance with the maintenance and repair instructions contained in this manual, in particular with regard to the specified tightening torques
- With the exclusive use of technical personnel trained in commissioning, operation, maintenance and repair

Any other use, particularly misuse, is considered as being contrary to the intended purpose. Such improper use increases the risk of injury and damage when working with the product. The manufacturer shall not be held liable for any damage resulting from improper, non-intended use.

The specifications of the manufacturer will be amended or supplemented as necessary. Prior to operation, make sure that the latest version is used. The latest version can be found at:

- <http://www.mtu-solutions.com>

Modifications or conversions

Unauthorized changes to the product represent a contravention of its intended use and compromise safety.

Changes or modifications shall only be considered to comply with the intended use when expressly authorized by the manufacturer. The manufacturer shall not be held liable for any damage resulting from unauthorized changes or modifications.

2.3 Personnel and organizational requirements

Organizational measures of the user/manufacturer

This manual must be issued to all personnel involved in operation, maintenance, repair, assembly, installation, or transportation.

Keep this manual handy in the vicinity of the product such that it is accessible to operating, maintenance, repair, assembly, installation, and transport personnel at all times.

Personnel must receive instruction on product handling and repair based on this manual. In particular, personnel must have read and understood the safety requirements and warnings before starting work.

This is important in the case of personnel who only occasionally perform work on or around the product. Such personnel must be instructed repeatedly.

Personnel requirements

All work on the product must be carried out by trained, instructed and qualified personnel only:

- Training at the Training Center of the manufacturer
- Qualified personnel from the areas mechanical engineering, plant construction, and electrical engineering and also for work with live parts

The operator must define the responsibilities of the personnel involved in operation, maintenance, repair, assembly, installation, and transport in writing.

Personnel shall not report for duty under the influence of alcohol, drugs or strong medication.

Clothing and personal protective equipment

Always wear appropriate personal protective equipment, e.g. safety shoes, ear protectors, protective gloves, goggles, breathing mask. Follow the instructions concerning personal protective equipment in the respective descriptions of the individual activities or the manufacturer's documentation included in the delivery.

When working on live components, in particular on electrical switchgear or on high-voltage component, wear special protective clothing according to IEC 61482.

Safe handling of Substances of Very High Concern pursuant to the REACH regulation (Registration, Evaluation, Authorization and restriction of CHemicals): We recommend wearing protective gloves at all times in order to reduce risk when working.

2.4 Safety regulations for commissioning and operation of electronic products

Safety regulations for commissioning

Install the product correctly and carry out acceptance in accordance with the manufacturer's specifications before putting the product into service. All necessary approvals must be granted by the relevant authorities and all requirements for initial startup must be fulfilled.

Whenever the product is subsequently taken into operation ensure that:

- All maintenance and repair work has been completed.
- All protective devices are in place.
- The power supply (power plug) must always be accessible to allow isolation of the equipment from supply voltage at any time.
- All components are properly grounded. Ground separately by means of a grounding stake as necessary.
- No persons wearing pacemakers or any other technical body aids are present.
- Adequate ventilation of the operating room must be ensured for any operating status.
- The product must be free of any damage, this applies in particular to lines and cabling.
- Protect battery terminals, generator terminals or cables against accidental contact.
- All connections are correctly arranged/assigned, e.g. polarization.

Immediately after putting the product into operation, make sure that all control and display instruments as well as the monitoring, signaling and alarm systems work properly.

Safety regulations during operation

The operator must be familiar with the control and display elements.

The operator must be familiar with the consequences of any operations performed.

During operation, the display instruments and monitoring units must be observed with regard to present operating status, violation of limit values and warning or alarm messages.

Malfunctions and emergency stop

Practice emergency procedures, especially emergency stopping, at regular intervals.

Take the following steps if any system malfunctions are detected or signaled by the system:

- Inform supervisor(s) in charge.
- Analyze the message.
- If required, carry out emergency operations e.g. isolate the equipment from the power supply.

Contact Service if the root cause of the malfunction cannot be clearly identified.

Operation of electrical equipment

When electrical equipment is in operation, certain components of these appliances are electrically live.

Follow the applicable operating and safety instructions when operating the devices and heed warnings at all times.

2.5 Safety regulations for assembly, maintenance, and repair work on electronic products

Safety regulations for work prior to assembly, maintenance, and repair

Have assembly, maintenance, or repair work carried out by qualified and authorized personnel only.

Never carry out assembly, maintenance, or repair work with the product in operation, unless:

- It is expressly permitted to do so following a written procedure.

Attach "Do not operate" sign in the operating area or to control equipment.

Use the recommended special tools or suitable equivalents when instructed to do so.

Safety regulations when performing assembly, maintenance, and repair work

Special tools and lifting equipment

Use only proper and calibrated tools.

Removing, installing and cleanliness

Pay particular attention to cleanliness at all times.

Working on electrical and electronic assemblies

Always obtain the permission of the person in charge before commencing assembly, maintenance, or repair work and before switching off any part of the electronic system required to do so.

De-energize the relevant areas prior to working on assemblies.

Follow the safety rules:

- Disconnect the electric system from live parts.
- Reliably prevent inadvertent power-on.
- Verify absence of voltage using suitable measuring/test equipment e.g. voltage indicator.
- Connect conductors and grounding with a short-circuiting device, e.g. grounding bar.
- Cover adjacent live parts. Prevent access by unauthorized persons.

ESD (Electrostatic Discharge): Work on components which could be damaged by electrostatic discharge must always be carried out with appropriate equipment. Appropriate equipment are e.g. electrically conductive work surfaces or antistatic wristbands.

Do not damage cabling during removal work. When reconnecting, ensure that cabling cannot be damaged during operation by:

- Contact with sharp edges
- Chafing on components
- Contact with hot surfaces.

Do not secure cables on lines carrying fluids.

Do not use cable ties to secure lines.

Always use connector pliers to tighten union nuts on connectors.

Never use the product as a climbing aid.

Subject the device as well as the product to functional testing on completion of all repair work. The emergency stop function must be tested in particular. The emergency stop function test involves the deactivation of the engine controller power supply. This test may only be performed when the product is cold.

Store spare parts properly prior to replacement, i.e. protect them against moisture in particular. Package faulty electronic components or assemblies properly before dispatching for repair:

- Moisture-proof
- Shock-proof
- Wrapped in antistatic foil (as necessary)