

Maintenance Schedule

Gas engine-generator set

MTU 6R400 GS - E3066Z5

MTU 12V400 GS - E3042Z6

MTU 6R400 GS - E3066Lx

MTU 12V400 GS - E3042Lx

MTU 6R400 GS - E3066LHx

MTU 12V400 GS - E3042LHx

Natural gas - interval: 1,000 - 50,000 operating hours

50Hz / 60Hz

MS50195/01E

SLU Name	Sales Name	Engine model		Application group
GG06R0400A1	MTU 6R400 GS	E3066Z5		3A, continuous operation, unrestricted
GG12V0400A1	MTU 12V400 GS	E3042Z6		3A, continuous operation, unrestricted
GG06R0400A1	MTU 6R400 GS	E3066Lx		3A, continuous operation, unrestricted
GG12V0400A1	MTU 12V400 GS	E3042Lx		3A, continuous operation, unrestricted
GG06R0400A1	MTU 6R400 GS	E3066LHx		3A, continuous operation, unrestricted
GG12V0400A1	MTU 12V400 GS	E3042LHx		3A, continuous operation, unrestricted

Table 1: Applicability

© 2016 MTU Onsite Energy GmbH, Augsburg

The original document was created in the German language.

This publication including all of its parts is protected by copyright. Each instance of use requires the prior written consent of MTU Onsite Energy GmbH. This applies in particular to duplication, dissemination, editing, translation, microfilming, and storage and/or processing in electronic systems, including databases and online services.

All of the information presented in this publication was current and up-to-date at the time of publishing. MTU Onsite Energy GmbH reserves the right to make changes to, delete, or supplement the provided information and data as needed.

Table of Contents

1	Maintenance Schedule		
1.1	Preface	4	
1.2	Additional notes on the maintenance of gas systems	5	
1.3	Checks by the operator	6	
1.4	Maintenance schedule matrix	9	
1.5	Maintenance schedule matrix - Module/engine-generator set/system	12	
1.6	Maintenance tasks		14
1.7	Maintenance tasks - Module/engine-generator set/system		16
2	Appendix A		
2.1	MTU Onsite Energy contact person / service partner		17

1 Maintenance Schedule

1.1 Preface

In the case of emission-certified products, nonobservance of the maintenance specifications can result in a violation of the statutory emission regulations. Modification or removal of mechanical or electronic components or the installation of additional components as well as the execution of calibration processes that might affect the emission characteristics of the product are prohibited by emission regulations. Emission-relevant components may only be maintained, exchanged or repaired if the components used for this purpose are approved by MTU or equivalent components. Emission-relevant components are for instance control units, data records, sensors, injectors, exhaust flaps and all components of exhaust aftertreatment systems.

The maintenance system for MTU products is based on a preventive maintenance concept. Preventive maintenance facilitates advance planning and ensures a high degree of equipment availability. The maintenance intervals and required maintenance scopes are based on operational experience and must therefore be regarded as recommendations. In the event of difficult operational and ambient conditions, additional maintenance tasks and/or changes to the maintenance intervals may be necessary.

Maintenance activities are specified with intervals based on hours in operation and time limits. The limit which occurs first is applicable.

The individual maintenance intervals are assigned to the qualification levels QL1 to QL4.

QL1: Operational checks and maintenance work that does not require disassembly of the product.

QL2: Component replacement (corrective, and thus not an element of the maintenance schedule).

QL3: Maintenance work that requires partial disassembly of the product.

QL4: Maintenance work that requires complete disassembly of the product.

Supplementary information on maintenance and preservation:

Change intervals for fluids and lubricants and details on preservation can be obtained in the relevant specifications of the component manufacturers and MTU Fluids and Lubricants Specifications. The latest version is also available at: <http://www.mtu-online.com>, for engine-generator sets at: <http://www.mtuonsiteenergy.com>.

Components which are not listed in this maintenance schedule must be serviced in accordance with Manufacturer's Instructions.

This maintenance schedule does not apply to engines with an EPA/CARB emission certificate.

1.2 Additional notes on the maintenance of gas systems

General information

The maintenance schedule matrix normally finishes with extended component maintenance or with engine overhaul. Following this, maintenance work is to be continued at the intervals indicated.

The numbers stated in the task list serve as a reference for the scope of parts required.



Repairs tasks on the gas system, for which the gas-conducting area is opened, and leak or stress tests must only be carried out by specialized companies. As a rule these are companies that are approved for the gas industry with qualified personnel who have been trained for technical gas applications.



The fluids and lubricants specification, the guidelines for maintenance and fluid and lubricant change as well as a list of recommended fluids and lubricants are contained in the Fluids and Lubricants Specifications of MTU Onsite Energy as well as in the fluids and lubricants specifications of the component manufacturers. They are therefore not included in the maintenance schedule (exception: deviations from the Fluids and Lubricants Specifications). Use only fluids and lubricants which comply with the Fluids and Lubricants Specifications of MTU Onsite Energy or which are approved by the relevant component manufacturer.

The following additional maintenance operations must be performed on direct responsibility of the operator / customer:

- Protect components made of rubber or synthetic material from oil. Never treat them with organic detergents. Wipe with a dry cloth only.
- Gas filter:
The maintenance interval depends on gaseous fuel quality (purity). Fuel filters upstream of the engine must be regularly cleaned and renewed if necessary.
- Battery:
Battery maintenance depends on duty and ambient conditions. The specifications of the battery manufacturer apply.

Items listed in this maintenance schedule but which are not included in the scope of delivery of MTU Onsite Energy may be disregarded.

Generator maintenance

Please refer to the Operating Instructions provided by the generator manufacturer for the intervals for these maintenance tasks.

Generator circuit breaker maintenance

Please refer to the Operating Instructions provided by the manufacturer for the intervals for these maintenance tasks.

Maintenance of non-MTU components

Please refer to the Operating Instructions provided by the relevant component manufacturer for the intervals for these maintenance tasks.

Maintenance tasks

The respective maintenance tasks to be carried out are based on operating hours (see the following pages).

1.3 Checks by the operator



Always observe the safety instructions.



Non-observance of these instructions may lead to damage to the system!



When using the unit supplied in a foreign country or in special regions, MTU Onsite Energy is not responsible for the adherence to the legal or other regulations / standards at the place of use.

Recommended daily checks – System

- Check exhaust gas piping for condensate leaks (visual inspection)
- Check condensate collecting tank downstream of condensate drain (if fitted)
- Carry out visual inspection of engine and plant for leaks / damage (bellows, hoses etc.)
- Check gas supply / gas system for damage (visual inspection)

Only for 60 Hz transmission units

- Oil temperature
- Storage temperature
- Oil pressure
- Oil contamination indicator
- Leaks
- Oil level
- Noise, vibrations

Recommended daily checks – Control system

The following measured values and functions are monitored by the control system to protect the plant. These messages can also be called up via remote access (option) and can be monitored by the customer in the display.

- Electric power
- Lube oil level
- Lube oil pressure
- Coolant temperature
- Coolant pressure
- Oxygen sensor voltage (option)
- Battery voltage
- Smooth running of engine
- Exhaust gas temperature
- Heating water supply and return temperature (option)
- Oil bleed system function (option)

Recommended weekly checks

- Lube oil consumption or content of fresh oil tank
- Engine room temperature
- Check of operating hours
- Check of number of starts
- Check of speed control for stability of regulator and the linkage (if installed)
- General visual inspection of module / engine-generator set

Only for 60 Hz transmission units

- Transmission mounting
- Outer condition of transmission (contamination, oil deposits)
- Visual condition of the transmission oil

Additional checks

The operator's gas installation (upstream of twin solenoid valve) must be inspected for leaks at the following intervals:

- Every year for engines with turbocharger
- Every six months for aspirated engines

The following checks are to be carried out at appropriate intervals, depending on the degree of contamination:

- Check room air fan and fresh air filter for contamination
- Check filter or air-conditioning unit for control cabinet for contamination
- Check recooler for contamination

Electrical systems

Electrical systems and operating equipment must be checked prior to initial commissioning, after repairs, prior to re-commissioning and at regular intervals. The intervals are to be so arranged that defects, which are to be expected, are detected at an early stage.

Here, among others, the following requirements apply:

- Accident prevention regulations BGV A3 "Electrical Systems and Operating Equipment"
- Technical rules for operational safety TRBS 2131 "Electrical Hazards"
- Industrial Safety Directive (BetrSichV)
- DIN VDE 0701/0702 Repairs, modifications and testing of electrical equipment/repeat tests on electrical units
- DIN EN 60204-1 Safety of machinery - Electrical equipment of machines

The operating company has the responsibility to see that these tests are carried out correctly. Electrical systems and fixed electrical operating equipment must be tested at appropriate intervals by a qualified electrician for their correct condition. The test is to include the following:

- Visual inspection and testing of protective equipment
- Testing of protective conductor resistance, insulation resistance, leakage current replacement, protective conductor current and differential current
- Carrying out fault diagnoses
- Preparation of test reports and inspection stickers

The industrial safety regulations, the technical rules for operational safety and the BGV A3 are fundamental with regard to adherence to the protective measures for "Electric Plants and Operating Equipment". The operating company is accordingly obligated to care for the safety of electrical systems and operating equipment.

	Designation
DIN	Deutsches Institut für Normung (Federal German Standards Institute)
EN	Europäische Normung (European Standards)
ISO	International Standards Organization
VDE	Verband der Elektrotechnik, Elektronik und Informationstechnik (Association for electrical engineering, electronics and information technology)
BGV	Berufsgenossenschaftliche Vorschriften (Trade association regulations)
TRBS	Technische Regeln für Betriebssicherheit (Technical rules for operational safety)

Table 2: Designations for standards and regulations



These regulations are contained in the manufacturers' instructions, legal requirements and technical guidelines valid in the individual countries. Since there can be major differences from country to country, it is not possible to provide a universally applicable statement on the rules to be observed within the framework of this maintenance schedule.

The user of the product mentioned herein is obligated to inform him-/herself about the provisions applicable in his/her country. MTU Onsite Energy does not accept any liability whatsoever for improper or unlawful use of the electric plant it has approved.

1.4 Maintenance schedule matrix

0-29,000 operating hours

Task		Limit	Operating hours [h]																														
			Daily	1,000	2,000	3,000	4,000	5,000	6,000	7,000	8,000	9,000	10,000	11,000	12,000	13,000	14,000	15,000	16,000	17,000	18,000	19,000	20,000	21,000	22,000	23,000	24,000	25,000	26,000	27,000	28,000	29,000	
Engine																																	
W0940			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0943			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0926			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0930			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0916			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0917			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0956			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0922			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0937			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0951			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0901			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0939			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0924			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0942			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0950			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0954			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0958			X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
W0953				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0918				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0921				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0929				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0907				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0915				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0944				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0904				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0928				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0927				X		X		X		X		X		X		X		X		X		X		X		X		X		X		X	
W0948						X				X				X				X				X				X				X			X
W0903						X				X				X				X				X				X				X			X
W0925							X					X					X					X						X					
W0952							X					X					X					X						X					
W0920							X					X					X					X						X					
W0905								X								X							X								X		
W0910												X											X										
W0908												X											X										
W0946												X											X										
W0949												X											X										
W0923													X														X						
W0936																X															X		
W0900																													X				
W0914																												X					
W0933																													X				
w = weeks m = months a = years																																	

Task	Limit	Operating hours [h]																			
		Daily	1,000	2,000	3,000	4,000	5,000	6,000	7,000	8,000	9,000	10,000	11,000	12,000	13,000	14,000	15,000	16,000	17,000	18,000	19,000
W0934																					X
W0906																					X
W0931																					X
W0913																					X
W0955																					X
W0935																					X
W0957																					
W0967																					
w = weeks m = months a = years																					

30,000-50,000 operating hours

Task	Limit	Operating hours [h]																													
		30,000	31,000	32,000	33,000	34,000	35,000	36,000	37,000	38,000	39,000	40,000	41,000	42,000	43,000	44,000	45,000	46,000	47,000	48,000	49,000	50,000									
Engine																															
W0940		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0943		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0926		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0930		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0916		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0917		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0956		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0922		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0937		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0951		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0901		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0939		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0924		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0942		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0950		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0954		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0958		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
W0953		X		X		X		X		X		X		X		X		X		X		X									
W0918		X		X		X		X		X		X		X		X		X		X		X									
W0921		X		X		X		X		X		X		X		X		X		X		X									
W0929		X		X		X		X		X		X		X		X		X		X		X									
W0907		X		X		X		X		X		X		X		X		X		X		X									
W0915		X		X		X		X		X		X		X		X		X		X		X									
W0944		X		X		X		X		X		X		X		X		X		X		X									
W0904		X		X		X		X		X		X		X		X		X		X		X									
W0928		X		X		X		X		X		X		X		X		X		X		X									
W0927		X		X		X		X		X		X		X		X		X		X		X									
W0948				X				X				X				X				X											
W0903				X				X				X				X				X											
W0925		X				X				X				X				X				X									
w = weeks m = months a = years																															