



Maintenance Schedule

Battery Energy Storage System (BESS)
mtu EnergyPack QL
2nd Generation

EPS50001/02E

Product name	Product type
mtu EnergyPack QL	EP40B1E

Table 1: Applicability

Table of Contents

1 Maintenance Schedule		1.2 Maintenance task tolerances	5
1.1 Preface	4	1.3 Cyclical maintenance tasks	6

1 Maintenance Schedule

1.1 Preface

This manual provides instructions for your product from the manufacturer Rolls-Royce Solutions.

Maintenance concept

The maintenance system for Rolls-Royce Solutions products is based on a preventive maintenance concept. Preventive maintenance facilitates advance operational planning and ensures a high level of operational availability. The maintenance intervals as well as the required scopes of maintenance tasks are based on operational experience and are therefore to be considered as recommendations. Additional maintenance work and/or changes to the maintenance intervals may be required in the case of difficult operational and ambient conditions.

Adherence to the specified maintenance intervals is essential to maintain product safety.

The intervals according to which the maintenance tasks have to be carried out are specified as operating hours and time limits. Whichever value is reached first shall apply.

The individual maintenance intervals are assigned to the qualification levels QL1 to QL3.

QL1: Operational monitoring and maintenance work which does not require disassembly of the product.

QL2: Exchange of components and parts in case of repair (corrective only, not part of the maintenance schedule).

QL3: Maintenance work which requires partial disassembly of the product.

Additional notes on maintenance and preservation:

Maintenance instructions specified in any documentation supplied by third-parties (vendors and component manufacturers), especially for components and subsystems, may differ from the information provided in this Maintenance Schedule. The Maintenance Schedule provided by Rolls-Royce Solutions applies in such case.

For the change intervals for fluids and lubricants and for information on preservation, refer to the relevant specifications of the component manufacturers and the Fluids and Lubricants Specifications. The latest version of the specifications is available at <http://www.mtu-solutions.com>

The relevant component manufacturer's instructions apply with respect to the maintenance of any components which do not appear in this Maintenance Schedule. This also includes the change intervals for fluids and lubricants and the specifications for preservation and represervation.