

**Diesel Engines  
V 396 TE 54****Maintenance Schedule  
M050387/21E**

MTU Motoren- und Turbinen-Union Friedrichshafen GmbH  
88040 Friedrichshafen / Germany  
Telephone (07541) 90-0  
Telex 734 280-0 mt d  
Telefax (07541) 90-3928

Low operating and maintenance costs as well as operational reliability and availability depend on maintenance and servicing being carried out in compliance with our specifications and instructions.

The overall system, of which the engine is an integral part, must be maintained in such a way as to ensure trouble-free engine operation at all times. For this purpose always:

- ensure that sufficient fuel is available,
- ensure that the combustion air is dry and clean,
- use only dry, clean compressed air,
- use only clean, filtered raw water.

Moreover, it is essential that:

- maintenance tasks be completed by trained personnel,
- suitable tools be used,
- genuine spare parts and fluids and lubricants as per the current MTU Fluids and Lubricants Specification A001061 be used.

Our Product Support Service will always be available should assistance be required.

Preventive maintenance instructions.

- Special care should be taken to keep the machinery plant in a clean and serviceable condition at all times to facilitate early detection of possible leaks and prevent subsequent damage.
- Protect rubber and synthetic components from oil and fuel, never treat with organic detergents. Wipe with a dry cloth only.

**MTU Maintenance Concept**

The maintenance concept for MTU products is a preventive maintenance concept and features the maintenance echelons W1 to W6 as outlined below.

Preventive maintenance facilitates advance planning and ensures a high degree of equipment availability.

**Main Features of Maintenance Tasks for MTU Engines.**

Maintenance Echelon W1: Operational Checks.

Maintenance Echelons W2, W3 and W4: Periodic maintenance tasks to be performed during out-of-service periods without the need for engine disassembly.

Maintenance Echelon W5: This echelon requires partial engine disassembly.

Maintenance Echelon W6: Major overhaul. This echelon requires complete engine disassembly.

The time intervals according to which the W2 to W6 Maintenance Echelons and the relevant checks and tasks involved are to be completed are based on operational experience. They have been determined so as to ensure correct engine operation until the next scheduled maintenance echelon.

Use of a maintenance predictor can mean changes to the operating hours given in the Maintenance Frequency Chart.

Specific operational conditions may require modification of the Maintenance Schedule.

**Note:**

The codes on the following pages indicate the groups and subgroups in the Engine Operation Manual (Part G - Task Description) in which the tasks involved are described.

This Maintenance Schedule may refer to parts which are not installed on your engine, these may be disregarded.