

Maintenance Schedule

Diesel Engine

6 R 1600 M20 F

Application Group 3A

MS50123/02E



Power. Passion. Partnership.

Table 1: Applicability

1 Maintenance Schedule

1.1 Preface

In the case of emission-certified products, nonobservance of the maintenance specifications can result in a violation of the statutory emission regulations. Modification or removal of mechanical or electronic components or the installation of additional components as well as the execution of calibration processes that might affect the emission characteristics of the product are prohibited by emission regulations. Components relevant to emissions, e.g. control units, sensors, cylinder heads, injectors and exhaust flaps can only be serviced, replaced or repaired if components approved by MTU, or equivalent components, are used.

The MTU maintenance system is based on a preventive maintenance concept. Preventive maintenance facilitates advance planning and ensures a high degree of equipment availability. The maintenance intervals and required maintenance scopes are based on operational experience and must therefore be regarded as recommendations. In the event of difficult operational and ambient conditions, additional maintenance tasks and/or changes to the maintenance intervals may be necessary.

The intervals according to which the maintenance tasks have to be carried out are specified as operating hours and time limits. The limit which occurs first is applicable.

The individual maintenance intervals are assigned to the qualification levels QL1 to QL4.

QL1: Operational monitoring and maintenance work which does not require disassembly of the product.

QL2: Component replacement (corrective, and thus not an element of the maintenance schedule).

QL3: Maintenance work that requires partial disassembly of the product.

QL4: Maintenance work that requires complete disassembly of the product.

Supplementary information on maintenance and preservation:

Change intervals for fluids and lubricants and details on preservation can be obtained in the relevant specifications of the component manufacturers and MTU Fluids and Lubricants Specifications. The latest version is available at: <http://www.mtu-online.com>.

Manufacturer's specifications shall apply to the maintenance of all components not listed in this maintenance schedule.

This maintenance schedule does not apply to engines with an EPA/CARB emission certificate.

Application Group

3A Continuous operation, unrestricted

Load profile

Load	110%	100%	75%	50%	30%	<10%
Corresponding operating time	<1%	3%	15%	40%	25%	16%