



Maintenance Schedule

Diesel Engine

12V1600Rx0

12V1600Rx0L

12V1600Rx1

12V1600Rx1L

Application group 2A

MS50137/03E

Engine model	kW/cyl.	Application group
12V1600R70	47 kW/cyl. (EU IIIB with SCR system)	2A, continuous operation, unrestricted
12V1600R70L	52 kW/cyl. (EU IIIB with SCR system)	2A, continuous operation, unrestricted
12V1600R80	55 kW/cyl. (EU IIIB with SCR system)	2A, continuous operation, unrestricted
12V1600R80L	58.3 kW/cyl. (EU IIIB with SCR system)	2A, continuous operation, unrestricted
12V1600R71	47 kW/cyl. (EU V with SCR system)	2A, continuous operation, unrestricted
12V1600R71L	52 kW/cyl. (EU V with SCR system)	2A, continuous operation, unrestricted
12V1600R81L	58.3 kW/cyl. (EU V with SCR system)	2A, continuous operation, unrestricted
12V1600R91	61.2 kW/cyl. (EU V with SCR system)	2A, continuous operation, unrestricted

Table 1: Applicability

Rolls-Royce Solutions refers to Rolls-Royce Solutions GmbH or an affiliated company pursuant to § 15 AktG (German Stock Corporation Act) or a controlled company (joint venture), and Rolls-Royce Solutions Ruhstorf GmbH.

© Copyright Rolls-Royce Solutions

This publication is protected by copyright and may not be used in any way, whether in whole or in part, without the prior written consent of Rolls-Royce Solutions. This particularly applies to its reproduction, distribution, editing, translation, microfilming and storage and/or processing in electronic systems including databases and online services.

All information in this publication was the latest information available at the time of going to print. Rolls-Royce Solutions reserves the right to change, delete or supplement the information provided as and when required.

Table of Contents

1 Maintenance Schedule		
1.1 Preface	4	
1.2 Special conditions	5	
1.3 Maintenance task tolerances	6	
1.4 Allocation matrix application group 2A	7	
1.5 Cyclical maintenance tasks 42000 HRS	8	
		1.6 Cyclical maintenance tasks 36000 HRS 10
		1.7 Cyclical maintenance tasks 30000 HRS 12
		1.8 Cyclical maintenance tasks 27000 HRS 14
		1.9 Cyclical maintenance tasks 24000 HRS 16
		1.10 Cyclical maintenance tasks 21000 HRS 18

1 Maintenance Schedule

1.1 Preface

This manual provides instructions for your product from the manufacturer Rolls-Royce Solutions.

Maintenance concept

The maintenance system for Rolls-Royce Solutions products is based on a preventive maintenance concept. Preventive maintenance facilitates advance operational planning and ensures a high level of equipment availability. The maintenance intervals as well as the required scopes of maintenance tasks are based on operational experience and therefore to be considered as recommendations. Additional maintenance work and/or changes to the maintenance intervals may be required in the case of difficult operational and ambient conditions.

Adherence to the specified maintenance intervals is essential to maintain product safety.

The intervals according to which the maintenance tasks have to be carried out are specified as operating hours and time limits. Whichever value is reached first shall apply.

The maintenance intervals are determined and verified by the load profile. Load profiles can be evaluated by the Service Partner of Rolls-Royce Solutions. Reading out load profile data is recommended for the first time after between 500 and 1000 operating hours depending on the application concerned, or after changing the duty profile or operating area.

The individual maintenance intervals are assigned to the qualification levels QL1 to QL4.

QL1: Operational monitoring and maintenance work which does not require disassembly of the product.

QL2: Exchange of components and parts in case of repair (corrective only, not part of the maintenance schedule).

QL3: Maintenance work which requires partial disassembly of the product.

QL4: Maintenance work which requires complete disassembly of the product.

Additional notes on maintenance and preservation:

The relevant component manufacturer's instructions apply with respect to the maintenance of any components which do not appear in this maintenance schedule.

For the change intervals of fluids and lubricants, refer to the corresponding Fluids and Lubricants Specifications.

If the product is to remain out of service for a longer time period, Rolls-Royce Solutions recommends to carry out a monthly test run until engine operating temperature is reached. If the engine is scheduled to remain out of service for > 1 month, carry out engine preservation procedures in accordance with the Preservation and Represervation Specifications

The latest version of the specifications is available at <http://www.mtu-solutions.com>.

1.2 Special conditions

Note

The engines are certified for operation with approved fuels as listed in the Fluids and Lubricants Specifications.

The maintenance intervals for the components specified in the maintenance schedule refer to engine operation with diesel fuel with a sulfur content < 15 ppm, e.g. EN 590.

If fuels with a sulfur content > 15 ppm are used, the maintenance intervals specified in the maintenance schedule for the affected components could be shorter.

Engines with exhaust gas recirculation and/or exhaust gas aftertreatment must not be operated with excessive sulfur content in the fuel. The limit values in the Fluids and Lubricants Specifications apply.

Table 2: Special conditions

1.3 Maintenance task tolerances

Maintenance tasks shall be completed within certain tolerances comprising a percentage and a maximum value, whereby the smaller value shall apply. Taking full advantage of such tolerances does not influence the scheduled timing of the ensuing maintenance task.

Interval (HRS)/limit	Limit in %	Limit max.
Operating hours	± 10%	± 500 hrs
Years	± 10%	± 30 days
Example 1	Task every 1000 hrs	Between 900 hrs and 1100 hrs (10% of 1000 hrs)
Example 2	Task every 30000 hrs	Between 29500 hrs and 30500 hrs (10% of 30000 hrs, but max. 500 hrs)

1.4 Allocation matrix application group 2A

Load profile		Load factor %	Load indicator %	0 to 47 kW/cyl.	48 to 55 kW/cyl.	56 to 58 kW/cyl.	58.3 kW/cyl.	61.2 kW/cyl.	
Load %	Time %								
110 ₍₁₀₀₋₁₁₀₎	0	0 to 40	≤ 12	42,000	36,000	30,000	27,000	24,000	Standard
100 ₍₉₀₋₁₀₀₎	8								
90 ₍₈₀₋₉₀₎	7								
80 ₍₆₅₋₈₀₎	2								
65 ₍₅₀₋₆₅₎	2								
50 ₍₃₀₋₅₀₎	3								
30 ₍₅₋₃₀₎	70								
Idle speed ₍₀₋₅₎	8	41 to 50	≤ 30	36,000	30,000	27,000	24,000	21,000	Load Profile
110 ₍₁₀₀₋₁₁₀₎	0								
100 ₍₉₀₋₁₀₀₎	27								
90 ₍₈₀₋₉₀₎	4								
80 ₍₆₅₋₈₀₎	8								
65 ₍₅₀₋₆₅₎	4								
50 ₍₃₀₋₅₀₎	8								
30 ₍₅₋₃₀₎	17	32							
Idle speed ₍₀₋₅₎	32								