

Process Pump Maintenance Standard

Standard practices for HX-series field service

Document ID	HEL-MAINT-2026
Version	2.0
Status	Approved
Effective date	20 April 2026
Owner	Global Service
Access	Service, Engineering; Sales read-only

Inspection intervals

Model	Routine inspection	Special note
HX-240	4,000 h	Seal inspection every 2,000 h in hot chemical service
HX-300	5,000 h	Shorten interval if cavitation or thermal cycling is observed
HX-400	6,000 h	3,000 h for severe thermal cycling
HX-520	1,500 h seal inspection	Follow validated hygienic maintenance plan where stricter

Evidence recording

- Capture model and serial number.
- Record operating temperature and pressure.
- Record fluid description and concentration when known.
- Record seal material and date of last replacement.
- Do not copy personal data from customer systems into the service note unless required.