

Proposal PR-2026-012 - Baltic Process OÜ

Technical-commercial proposal for Industrial water treatment application

Proposal ID	PR-2026-012
Customer	Baltic Process OÜ
Country	Estonia
Date	2026-02-02
Status	Closed / Historical
Owner	Helios Sales Engineering
Access	Sales, Service

1. Customer requirement

Requirement	Customer condition
Fluid	Filtered industrial water
Operating temperature	72°C
System pressure	14 bar
Required flow	90 m³/h
Duty	Continuous

2. Proposed solution

HX-300 standard FKM configuration

Pressure requirement exceeds HX-240 capability; HX-300 provides suitable pressure margin.

Reference product limits considered during proposal preparation: 16 bar maximum pressure; 110°C continuous fluid temperature; 20-120 m³/h flow range.

3. Configuration notes

- Wetted material: 316L stainless-steel wetted parts.
- Seal arrangement: FKM mechanical seal.
- Final motor sizing to be confirmed against detailed duty point and site electrical standard.
- Installation design, pipe stress and NPSH validation remain customer / EPC responsibilities unless explicitly included.

4. Commercial assumptions

- Proposal is based on the stated process conditions only.
- Material and seal compatibility are subject to complete fluid information.
- Any change in temperature, pressure, fluid composition or duty cycle requires review.
- This historical proposal is provided as enterprise knowledge and is not a current quotation.

5. Sales-engineering note

This proposal may be used as precedent for similar applications, but the current approved product documentation and latest customer conditions must take precedence.