


NOTE(S):  
1-REFER P & ID 3563-R-DB-0000-002 FOR LEGEND AND GENERAL NOTES  
2-ALL CONNECTIONS FROM TOP OF HEADER  
3-MANHOLES EXTENDED OUTSIDE THE EARTH MOUND  
4-VESSELS WITH 1.0M MIN. EARTH MOUNDING  
5-VORTEX BREAKER SHOULD BE INSTALLED.  
6-SPRING LOADED BALL VALVE WITH 90° ROTATION.

**APPROVED**  
By Ismail at 10:02 am, Dec 17, 2014


13	28.07.12	AS BUILT	ZMS	UAM	-
12	17.12.03	SECOND AS BUILT	MAA	IU	SNR
11	3.7.2K	FIRST AS BUILT	MIM	IU	SNR
10	06-12-99	AS BUILT	YM	ZM	IA
9	09-02-99	AS MARKED	YM	ZM	MH
8	06-02-99	AS MARKED	YM	ZM	MH
REV	DATE	DESCRIPTION	INIT. BY	SIGN	INIT. APP'VD
REVISIONS					
UNAUTHORIZED REPRODUCTION OF ANY KIND IS PROHIBITED; ALL RIGHTS ARE RESERVED BY DESCON ENGINEERING LIMITED, LAHORE, PAKISTAN					

**DESCON ENGINEERING LTD.**  
P.O. BOX 1201, LAHORE 54000, PAKISTAN

ORIGINAL	INIT.	SIGN	DATE	E.F.	NAME
ENGINEERED	DRZA		6/12		L4R005M
DRAWN	YM		6/12		
CHECKED	ZM		6/12		
APPROVED	IA		6/12		

THIS DOCUMENT HAS BEEN  
MODIFIED MANUALLY  
☐ YES ☒ NO

EPTL DOC. NO.	DOCUMENT NUMBER	SHEET	REV.
DR00511	3563-R-DB-0000-005-*	NO. 1	OF 1

**ENGRO PAKTANK**  
TERMINAL LTD.

PROJECT LPG STORAGE & HANDLING

TITLE  
**P & ID**  
**PROPANE/BUTANE STORAGE**

SHEET	REV.
NO. 1	OF 1