



NOTE (S):

- 1-REFER P&ID 35-3-R-DB-0000-002 FOR LEGEND AND GENERAL NOTES
- 2-ALL CONNECTIONS FROM THE TOP OF HEADER
- 3-MANHOLDS EXTENDED OUTSIDE THE EARTH MOUND
- 4-VESELS WITH 1.0M MIN. EARTH MOUNDING
- 5-VORTEX BREAKER SHOULD BE INSTALLED.
- 6-NOZZLE N2 WILL BE EXTENDED OUTSIDE THE EARTH MOUND HORIZONTALLY
AND THEN VALVES WILL BE INSTALLED FOR ISOLATION AND DRAIN.
- 7-NOZZLE N8 WILL BE EXTENDED INSIDE THE VESSEL.
- 8-SPRING LOADED BALL VALVE WITH 90° ROTATION.

[illegible]

DESCON ENGINEERING LTD.
P.O. BOX 1201, LAHORE 54000, PAKISTAN

ORIGINAL	INIT.	SIGN	DATE	E.F. NAME	
ENGINEERED	DRZA		6/12	L4R008M	
DRAWN	YM		6/12	SIZE	SCALE
CHECKED	ZM		6/12		
APPROVED	IA		6/12	A3	NTS

THIS DOCUMENT HAS BEEN
MODIFIED MANUALLY
☐ YES ☒ NO

EPTL DOC. NO.

CLIENT   ENGRO PAKTANK
TERMINAL LTD.

PROJECT LPG STORAGE & HANDLING

TITLE	P & ID
PROPANE/BUTANE STORAGE	

EPTL DOC. NO.						DOCUMENT NUMBER						SHEET		REV.	
D	R	0	0	8	1	1	3563-R-DB-0000-008-*						NO.		OF
													1	1	14