# Pak Matiari-Lahore Transmission Company (Private) Limited

## 巴基斯坦默蒂亚里拉合尔输电(私人)有限公司

Ref. No.: PTC-02-20210507-01 Dated: May 7, 2021

### **Chief Engineer (HVDC)**

National Transmission & Despatch Company Limited (NTDCL) Room 618, WAPDA House, Lahore

Project: ±660kV Matiari - Lahore HVDC Transmission Project

Subject: NTDC Suggestions Regarding Additional Commissioning Test (A-7) and

**Submission of Schedule** 

Reference: [1] Your letter No. Ref 3930-37, dated May 6, 2021.

#### Dear Sir,

With reference to your letter mentioned above, vide which you again request PMLTC to conduct additional commissioning test (A-7), PMLTC hereby clarify as below:

- 1. No additional commissioning test (A-7) is requested under TSA except DC line fault locator accuracy test, which has been carried out and successfully completed during Low Power Test (A4).
- 2. PMLTC can make arrangement for test as good will if NTDC insists the additional commissioning test (A7), However, the additional commissioning test (A7) should not be the pre-requisite of High Power Test (A5).
- 3. As to specific item, please refer to the following:

No.	Item	PMLTC Comments
1	Last line protection test	We have replied this point vide out letter No. PTC-02-20210430-1 dated 30-4-2021, however, if NTDC insists, PMLTC will cooperate with NTDC/NPCC/OE to finalize the test procedure.
2	Electrode line open circuit test	It has been performed and successfully completed during Low Power Test (A4). Please refer to test item 140 and 141(6.3.1).
3	Overload timer automatic reset test	It will be performed during high power test (A5).
4	Electrode line ground fault in bipolar mode test	If NTDC insist, PMLTC can provide a procedure and make arrangement.

Address: No.581-Z, Street-17, Phase III, DHA, Lahore, Pakistan

Tel: +92-42-3574 6855 Fax: +92-42- 3574 6869

# Pak Matiari-Lahore Transmission Company (Private) Limited 巴基斯坦默蒂亚里拉合尔输电 (私人) 有限公司

5	DC line fault locator	It has been performed and successfully completed during
	accuracy test	low power test (A4).
6	Electrode line ground	If NTDC insists, PMLTC can provide a procedure and
	fault in monopolar test	make arrangement.

Sincerely Yours,

Ma Desheng

Deputy CEO

Pak Matiari-Lahore Transmission Company (Pvt.) Ltd.

#### C.C

- > Dy. Managing Director (NTDC), 419-Wapda House, Lahore.
- > GM (SO) NPCC NTDC, Islamabad for coordination.
- M/s HATCH Canada.

Address: No.581-Z, Street-17, Phase III, DHA, Lahore, Pakistan

Tel: +92-42-3574 6855 Fax: +92-42- 3574 6869