MLHVDC-LCS-ECI-DD-WF-0104-001A

30-B003701S-S0104-001

巴基斯坦默蒂亚里—拉合尔±660kV 直流输电工程

拉合尔±660kV 换流站工程

±660kV HVDC Project from Matiari to Lahore in Pakistan

±660kV Lahore Converter Station

施工图设计
Detail Design

消 防 部 分

Fire Fighting Part

消防设备及材料清册

List of Fire Fighting System Equipment and Major Materials

a) 中国电力技术装备有限公司
China Electric Power Equipment and Technology Co., Ltd.
b) 中国电力工程顾问集团华东电力设计院有限公司
East China Electric Power Design Institute of China Power Engineering Consulting Group
June, 2019

拉合尔±660kV 换流站 工程

施工图 阶段

	中国电力工程顾问集团华东电力设计院有限公司 工程设计综合资质甲级 A131000025 工程勘察综合类甲级 B131000025

卷册检索号		30	B003701S		S0104			
文本编号		B003701S		S0104			001	
0	201906	CFC	新制					
版号	日期	状态	修改内容摘要	设计	校核	审核		批准

本文件的知识产权为华东电力设计院有限公司所有，任何单位或个人未经许可不得复制和使用，违者将被追究法律责任。

批准	2019.06		消防设备及材料清册 Design List of FireIghting System Equipment and Major Materials	
审核	2019.06			
校核	2019.06			
设计	2019.06			
日期 2019.06	状态	CFC	版号	A

编号	名称	规格	单位	数量	备注
1	XBC9/220-S 型 柴油机消防泵组	Q=800m^3/h H=90m N=351kW	套	1	合同已定，由坚瑞永安安全系统工程有限公司负责供货，参见有关技术协议，包括包括配套柴油机、油箱、消音器、地脚螺栓、进出口法兰、进出水压力表等配件等配件。
2	XBD9.5/115-SLOW 型 电动机消防泵组	Q=450m^3/h H=90m N=200kW	套	2	合同已定，由坚瑞永安安全系统工程有限公司负责供货，参见有关技术协议，包括包括配套电动机、地脚螺栓、进出口法兰、进出水压力表等配件等配件
3	消防气压稳压装置	有效容积 3.60m^3， ∅2400mm，工作压力 1.6MPa	套	1	合同已定，由坚瑞永安安全系统工程有限公司负责供货,参见有关技术协议.包括气压罐、稳压泵、地脚螺栓、阀门、控制柜、进出水压力表等配件
4	消防泵控制柜	巡检柜、联络柜、双电源切换柜、稳压控制柜及柴泵控制柜等	套	1	合同已订，由坚瑞永安安全系统工程有限公司负责供货，参见有关技术协议书。
5	电动单梁悬挂起重机	5t，跨度 6.5m，最大起升高度 9m	套	1	合同已订，由坚瑞永安安全系统工程有限公司负责供货，参见有关技术协议书。
6	80WQ50-10-3kW 型 潜水排污泵	Q=50m^3/h H=10m	套	2	合同已订，由坚瑞永安安全系统工程有限公司负责供货，由广州市昕恒泵业制造有限公司供货，

本文件的知识产权为华东电力设计院有限公司所有，任何单位或个人未经许可不得复制和使用，违者将被追究法律责任

编号	名称	规格	单位	数量	备注
		N=3kW			参见有关技术协议书。包括浮子开关、就地控制柜及出口反法兰。一套安装，一套放置于备品备件库
7	50WQ15-8-0.75kW 型潜水排污泵	Q=5m^3/h H=8m N=0.75kW	套	2	合同已订，由坚瑞永安安全系统工程有限公司负责供货，由广州市昕恒泵业制造有限公司供货，参见有关技术协议书。包括浮子开关、就地控制柜及出口反法兰。一套安装，一套放置于备品备件库
8	换流变水喷雾灭火系统				
（1）	雨淋阀箱		套	4	合同已订，由坚瑞永安安全系统工程有限公司负责供货，参见有关技术协议书。
（2）	Y 型过滤器	DN300,PN=1.6MPa	套	8	含卡箍或法兰等连接配件
（3）	蝶阀	DN300,PN=1.6MPa	只	16	含卡箍或法兰等连接配件
（4）	雨淋阀组	DN250,PN=1.6MPa	只	12	合同已订，由坚瑞永安安全系统工程有限公司负责供货，含前后信号蝶阀、基本配管、电动配管、水力警铃、压力开关、就地控制箱等。参见有关技术协议书。

本文件的知识产权为华东电力设计院有限公司所有，任何单位或个人未经许可不得复制和使用，违者将被追究法律责任

编号	名称	规格	单位	数量	备注
（5）	高速水雾喷头				合同已订，由坚瑞永安安全系统工程有限公司负责供货。采用离心雾化型水雾喷头(带柱状过滤网)。参数及数量详见施工图图纸。
9	柴油机消防泵水喷雾灭火系统				
（1）	雨淋阀组	DN150 PN1.6	套	1	合同已订，由坚瑞永安安全系统工程有限公司负责供货。含前后信号蝶阀、基本配管、电动配管、水力警铃、压力开关、就地控制箱
（2）	Y 型过滤器	DN100 PN=1.6MPa	套	1	
（3）	闸阀	DN100 PN=1.6MPa	套	1	
（4）	高速水雾喷头				合同已订，由坚瑞永安安全系统工程有限公司负责供货。采用离心雾化型水雾喷头(带柱状过滤网)。参数及数量详见施工图图纸。

备注：1、材料部分的内容详见本工程各施工图卷册内的材料汇总表。

本文件的知识产权为华东电力设计院有限公司所有，任何单位或个人未经许可不得复制和使用，违者将被追究法律责任

No.	Name	Type and Specification	Unit	Quantity	Remark
1	Diesel fire pump set XBC9/220-S Type	Q=800m^3/h H=90m N=351kW	Set	1	Contract ordered, refers to related technical agreements. Supporting diesel engine、Diesel tank、silencer、anchor bolt、inlet& outlet flange、pressure gage etc included
2	Motor fire pump set XBD9.5/115-SLOW	Q=450m^3/h H=90m N=200kW	Set	2	Contract ordered, refers to related technical agreements. Motor、anchor bolt、inlet& outlet flange、pressure gage etc included
3	Pressure Stabilizing Device	Effective capacity:3.60m^3; Ø2400mm;Working pressure1.6MPa	Set	1	Contract ordered, refers to related technical agreements. Pressure tank、stabilized pressure pump valves、 anchor bolt、control cabinet、inlet& outlet flange、pressure gage etc included
4	Fire pump control cabinet	Inspection cabinet, Contact cabinet, Dual power switch cabinet, Voltage stabilization control cabinet and diesel pump cabinet etc	Set	1	Contract ordered, refers to related technical agreements.
5	Electric Crane	5t，span:6.5m，	Set	1	Contract ordered, refers to related technical

本文件的知识产权为华东电力设计院有限公司所有，任何单位或个人未经许可不得复制和使用，违者将被追究法律责任

No.	Name	Type and Specification	Unit	Quantity	Remark
		Maximum lifting height:9m			agreements.
6	Submersible sewage pump 80WQ50-10-3kW Type	Q=50m^3/h H=10m N=3kW	Set	2	Float switch、local control cabinet and outlet flange included. One set of installation, one set placed in the spare parts storage.
7	Submersible sewage pump 50WQ15-8-0.75kW Type	Q=5m^3/h H=8m N=0.75kW	Set	2	Float switch、local control cabinet and outlet flange included. One set of installation, one set placed in the spare parts storage.
8	Water Spray System for Converter Transformers				
（1）	Deluge Valve Box		Set	4	Contract ordered, refers to related technical agreements.
（2）	Y type filter	DN300,PN=1.6MPa	Set	8	including connection fittings，such as clamps or flange etc.
（3）	Butterfly valve	DN300,PN=1.6MPa	Set	16	including connection fittings，such as clamps or flange etc.
（4）	Deluge valve	DN250,PN=1.6MPa	Set	12	Contract ordered, refers to related technical

本文件的知识产权为华东电力设计院有限公司所有，任何单位或个人未经许可不得复制和使用，违者将被追究法律责任

No.	Name	Type and Specification	Unit	Quantity	Remark
					agreements.
（5）	High speed water spray nozzle				Contract ordered, refers to related technical agreements. Type and Quantity refers to 30-B003701S-S0505.
9	Water Spray System for Diesel Pump				
（1）	Deluge valve	DN150 PN1.6	Set	1	Contract ordered, refers to related technical agreements.
（2）	Y type filter	DN100,PN=1.6MPa	Set	1	including connection fittings，such as clamps or flange etc.
（3）	Gate valve	DN100,PN=1.6MPa	Set	1	including connection fittings，such as clamps or flange etc.
（4）	High speed water spray nozzle				Contract ordered, refers to related technical agreements. Type and Quantity refers to 30-B003701S-S0506.

Remark：Detailed Materials refer to bill of materials in each construction drawing volume.

本文件的知识产权为华东电力设计院有限公司所有，任何单位或个人未经许可不得复制和使用，违者将被追究法律责任