




CONTRACTOR'S		PAKHTUNKHAWA HIGHWAY AUTHORITY (PKHA)		CONSULTANT'S	
		CONSTRUCTION OF TORGHAR BRIDGE OVER INDUS RIVER (KANHAR SHARIF SITE)			
ALM-HASAS (JV)				CEC-AA ASSOCIATES (JV)	

CONCRETE COMPRESSIVE STRENGTH (AASHTO T-22 / ASTM C-39)					
Req No	66	Concrete Class	A-3	Lab No	21
Req Date	08-07-24	Initial 'Conc. Temp. °C	28.0	Casting Date	09-07-24
Tested by	Jointly	Req. Strength kg/cm ²	280	Initial Slump (mm)	150
Structure	Pier # I, Pile # 14				

07 Days						
Cylinder No	Testing Date	Age Days	Load (KN)	Area (cm ²)	Compressive Strength (kg/cm ²)	Avg. Strength (kg/cm ²)
1	16-07-2024	07	450.0	182.4	251.6	246.6
2		"	430.0	"	240.4	
3		"	443.0	"	247.7	
7 days (Kg/cm ²)						

28 Days						
Cylinder No	Testing Date	Age Days	Load (KN)	Area (cm ²)	Compressive Strength (kg/cm ²)	Avg. Strength (kg/cm ²)
4	07-08-2024	28	587.0	182.4	328.2	314.7
5		"	558.0	"	312.0	
6		"	543.5	"	303.8	
28 days (Kg/cm ²)						

Remarks: 28 days compressive strength found ok.

CONTRACTOR'S	CONSULTANT'S
SLT/LT: -	SLT/LT:
Material Engineer: 	Material Engineer: 