


CONTRACTOR'S		PAKHTUNKHAWA HIGHWAY AUTHORITY (PKHA)			CONSULTANT'S	
 		CONSTRUCTION OF TORGHAR BRIDGE OVER INDUS RIVER (KUNHAR SHARIF SITE)			 	
ALM-HASAS (JV)					003	
CONCRETE COMPRESSIVE STRENGTH (AASHTO T-22 / ASTM C-39)						
Req No	73	Concrete Class	A3	Lab No	25	
Req Date	27-07-2024	Conc. Temp. °C	30.8	Casting Date	27-07-2024	
Tested by	Jointly	Req. Strength kg/cm ²	280	Slump (mm)	200	
Structure	Pile # 07 ABL					
07 Days						
Cylinder No	Testing Date	Age Days	Load (KN)	Area (cm ²)	Compressive Strength (kg/cm ²)	Avg. Strength (kg/cm ²)
1	03-08-2024	7	451.2	182.4	252.2	257.4
2		7	470.4	"	263.0	
3		7	459.5	"	256.9	
7 days (kg/cm ²)						
28 Days						
Cylinder No	Testing Date	Age Days	Load (KN)	Area (cm ²)	Compressive Strength (kg/cm ²)	Avg. Strength (kg/cm ²)
4	24-08-2024	28	548.3	182.4	306.5	305.4
5		28	539.8	"	301.8	
6		28	550.5	"	307.8	
28 days (kg/cm ²)						
Remarks: <u>checked and found ok.</u>						
CONTRACTOR'S				CONSULTANT'S		
SLT/LT:				SLT/LT:		
Material Engineer: 				Material Engineer: 