

CONTRACTOR'S		PAKHTUNKHAWA HIGHWAY AUTHORITY (PKHA) CONSTRUCTION OF TORGHAR BRIDGE OVER INDUS RIVER (KUNHAR SHARIF SITE)	CONSULTANT'S
 			 
ALM-HASAS (JV)			AA-ASSOCIATE-CEC (JV)


002

CONCRETE COMPRESSIVE STRENGTH (AASHTO T-22 / ASTM C-39)					
Req No	76	Concrete Class	A-3	Lab No	26
Req Date	31-07-2024	Conc. Temp. °C	30.6	Casting Date	31-07-2024
Tested by	Jointly	Req. Strength kg/cm ²	280	Slump (mm)	190
Structure	Pile #05 ABL				

07 Days						
Cylinder No	Testing Date	Age Days	Load (KN)	Area (cm ²)	Compressive Strength (kg/cm ²)	Avg. Strength (kg/cm ²)
1	07-08-2024	7	466.7	182.4	260.9	265.4
2		7	481.1	"	269.0	
3		7	476.6	"	266.4	
7 days (kg/cm ²)						

28 Days						
Cylinder No	Testing Date	Age Days	Load (KN)	Area (cm ²)	Compressive Strength (kg/cm ²)	Avg. Strength (kg/cm ²)
4	28-08-2024	28	577.3	182.4	322.7	317.2
5		28	565.8	"	316.3	
6		28	559.2	"	312.6	
28 days (kg/cm ²)						

Remarks	checked and found ok.

CONTRACTOR'S		CONSULTANT'S	
SLT/LT:		SLT/LT:	
Material Engineer:		Material Engineer:	