


 A.A. ASSOCIATES, Planners & Consulting Engineers  CREATIVE ENGINEERING CONSULTANTS		GOVERNMENT OF KHYBER PAKHTUNKHWA PAKHTUNKHWA HIGHWAYS AUTHORITY ADP SCHEME NO. 1494/220942 (2022-23) CONSTRUCTION OF RCC BRIDGE ON RIVER INDUS NEAR KOTKAY KANDAR, DISTRICT TORGHAR	 AL-MEHREEN JV HASAS
CONSULTANT		CONTRACTOR	
REQUEST FOR INSPECTION			
REQUEST NO: 76		Time: 12:29	Date: Fri Aug 02 2024
Chainage	Description		
River Rd, Tor Ghar Pakistan	Check the Concrete pouring of pile No.05		
Submission		Inspection	
Date: Fri Aug 02 2024 Time: 12:29		Date: Wed Jul 31 2024 Time: 20:00	
			
Inspector :		Signature :	
Surveyor :		Signature :	
LT/SLT :		Signature :	
ME :		Signature :	
ARE :		Signature :	
Satus : <u>Not Approved</u> Note : _____ Resident Engineer :			


CONTRACTOR'S		PAKHTUNKHAWA HIGHWAY AUTHORITY (PKHA)		CONSULTANT'S	
 		CONSTRUCTION OF TORGHAR BRIDGE OVER INDUS RIVER (KUNHAR SHARIF SITE) 002		 	
ALM-HASAS (JV)				AA-ASSOCIATE-CEC (JV)	

CONCRETE COMPRESSIVE STRENGTH (AASHTO T-22 / ASTM C-39)					
Req No	76	Concrete Class	A-3	Lab No	26
Req Date	31-07-2024	Conc. Temp. °C	30.6	Casting Date	31-07-2024
Tested by	Jointly	Req. Strength kg/cm ²	280	Slump (mm)	190
Structure	Pile #05 ABL				

07 Days						
Cylinder No	Testing Date	Age Days	Load (KN)	Area (cm ²)	Compressive Strength (kg/cm ²)	Avg. Strength (kg/cm ²)
1	07-08-2024	7	466.7	182.4	260.9	265.4
2		7	481.1	"	269.0	
3		7	476.6	"	266.4	
7 days (kg/cm ²)						

28 Days						
Cylinder No	Testing Date	Age Days	Load (KN)	Area (cm ²)	Compressive Strength (kg/cm ²)	Avg. Strength (kg/cm ²)
4	28-08-2024	28	577.3	182.4	322.7	317.2
5		28	565.8	"	316.3	
6		28	559.2	"	312.6	
28 days (kg/cm ²)						

Remarks	checked and found ok.

CONTRACTOR'S	CONSULTANT'S
SLT/LT:	SLT/LT:
Material Engineer: 	Material Engineer: 