Estimating in Building Construction

Chapter 19 Heating, Ventilating, and Air-conditioning

HVAC

- Usually subcontracted out

Includes

- Heating equipment
- Cooling equipment
- Thermostats
- Ductwork
- Diffusers
- Dehumidifiers
- Fans
- Insulation
- Return air
- Fresh air
- Louvers
- Associated piping
- Associated wiring

Coordination Requirements

- Underground utilities
  - Location, size, excavation by whom, from where?
- Equipment
  - Method of support, location, by whom, anchors, access for receiving and installing, size limitations

Coordination Requirements

- Piping
  - Wall sleeves, size limitations, in walls, under floors, floor sleeves, expansion compensators, access doors.

Coordination Requirements

- Ductwork
  - Sizes, support, access doors, drops, outlet sizes, outside air louvers.

Coordination Requirements

- Terminal equipment
  - Recesses for cabinet unit heater (CUH), size of radiation, method of concealing, fastenings.
- Mechanical-electrical responsibility
  - Who is doing what?

Coordination Requirements

- Finishes
  - Field or factory?
- Scheduling
  - Work to be done? When required? Job to be completed on time-who, why, when?

Thank You