



Gulf Star Lab

Water, Food & Environmental Testing

Saudi Arabia — القطيف — منطقة المستودعات — P.O. Box 31972
C.R: 300399366200003

RESULT REPORT

Laboratory Analysis



WATER-26-0080

TEST INFORMATION		SAMPLE INFORMATION	
Test Reference	TEST-2026-0270	Lab Job No	WATER-26-0080
Client Name	BGP Arabia CO. Ltd	Sample ID	WATER
Client ID	SHOWER WATER BASE CAMP 03	Sample Type	Water
E-MAIL / Phone	59 090 0602	Location	S-92
Report Date	12 / 08 / 2026	Sample Date	06 / 08 / 2026

ANALYSIS RESULTS

S	Analysis Type	Parameter / Testing	Method	Result	Unit	STD
1	Chemistry and Microbiology	Color	****	OK	****	NIL
2	Chemistry and Microbiology	Odor	***	OK	***	NIL
3	Chemistry and Microbiology	pH	APHA 4500-H+B	7.98	pH meter	6.5 - 8.5
4	Chemistry and Microbiology	Temperature	APHA 2550 B	24	C	*****
5	Chemistry and Microbiology	TOTAL DISSOLVED SOLIDS - TDS	APHA 2540 C	770	mg/l	100 - 500
6	Chemistry and Microbiology	Conductivity	APHA 2510	1316	us/cm	160 - 1000
7	Chemistry and Microbiology	Turbidity	APHA 2130	<1	FAU	< 1
8	Chemistry and Microbiology	Sulphate - SO ₄	APHA 3120/USEPA	205	mg/l	< 250
9	Chemistry and Microbiology	CHLORIDE - Cl- كلورايد	APHA 2330	127.6	mg/l	0 - 200
10	Chemistry and Microbiology	Total Hardness العسر الكلي	APHA 2340	390	mg/l	0 - 200
11	Chemistry and Microbiology	Calcium - Ca ²⁺	APHA 2340	104	mh/l	0 - 100
12	Chemistry and Microbiology	MAGNESIUM - Mg ²⁺ ماغنيسيوم	APHA 2340	31.7	mg/l	0 - 100
13	Chemistry and Microbiology	Free / Residual Chlorine	APHA 3120	0.01	mg/l	0 - 0.05
14	Chemistry and Microbiology	Iron Fe ²⁺ , 3 ⁺	APHA-4500-Fe	0.02	mg/l	< 0.3
15	Chemistry and Microbiology	Nitrate NO ₃	APHA 4500-NO ₃	0.9	mg/l	< 45
16	Chemistry and Microbiology	Sodium (Na)	SM-3500-Na-B	69.5	mg/l	< 90

ANALYSIS RESULTS

S	Analysis Type	Parameter / Testing	Method	Result	Unit	STD
17	Chemistry and Microbiology	Potassium (K)	SM-3500-K-B	5.5	mg/l	0 - 10
18	Chemistry and Microbiology	E. coli	ISO 9308-1:2014/Amd 1:2016	<Negative	CFU/100ml	Negative
19	Chemistry and Microbiology	Total Coliform	ISO 9308-1:2014/Amd 1:2016	Positive	CFU/100ml	Negative

REMARKS & COMMENTS

Some cations and anions are above the recommended limit. Coliform is detected in the sample. Not recommended for shower



Wael Alramadhan



Lab Manager

Name & Signature