



Gulf Star Lab

Water, Food & Environmental Testing

Saudi Arabia — القطيف — منطقة المستودعات — P.O. Box 31972
C.R: 300399366200003

RESULT REPORT

Laboratory Analysis



WATER-26-0093

TEST INFORMATION		SAMPLE INFORMATION	
Test Reference	TEST-2026-0283	Lab Job No	WATER-26-0093
Client Name	SADA AL ARAB TRADING CO سعادة	Sample ID	WATER
Client ID	HWU 7 MAIN CAMP AB260013	Sample Type	Water
E-MAIL / Phone	—	Location	KHOB
Report Date	12 / 08 / 2026	Sample Date	06 / 08 / 2026

ANALYSIS RESULTS

S	Analysis Type	Parameter / Testing	Method	Result	Unit	STD
1	Microbiology	Total Plate Count - TPC	ISO 6222:1999	900	CFU/ml	< 100
2	Microbiology	Total Coliform بكتيريا	ISO-9308-1: 2014	<1	CFU/100 ml	< 1

REMARKS & COMMENTS


Wael Alramadhan



Lab Manager

Name & Signature