



Gulf Star Lab

Water, Food & Environmental Testing

Saudi Arabia — القطيف — منطقة المستودعات — P.O. Box 31972
C.R: 300399366200003

RESULT REPORT

Laboratory Analysis



WATER-26-0306

TEST INFORMATION		SAMPLE INFORMATION	
Test Reference	TEST-2026-0598	Lab Job No	WATER-26-0306
Client Name	SADA AL ARAB TRADING CO سعادة	Sample ID	WATER
Client ID	AB260024	Sample Type	Water
E-MAIL / Phone	—	Location	*
Report Date	14 / 09 / 2026	Sample Date	05 / 09 / 2026

ANALYSIS RESULTS


S	Parameter / Testing	Method	Result	Unit	STD
1	Color	-----	nil	-----	Nil
2	Odor	***	Not ok	***	NIL
3	pH	APHA 4500-H+B	6.82	pH meter	6.5 - 8.5
4	Total Dissolved Solids - TDS مجموع الأملاح الذائبة	APHA 2540 C	550	mg/l	100 - 500
5	Turbidity	APHA 2130	<1	FAU	< 1
6	Conductivity	APHA 2510	1108	us/cm	160 - 1000
7	Sulphate SO4 كبريتات	APHA 3120/USEPA	21	mg/l	< 250
8	Fluoride - F-	APHA 4500F- C	0.06	mg/l	< 1.50
9	CHLORIDE - Cl- كلورايد	APHA 2330	283	mg/l	0 - 200
10	Total Hardness العسر الكلي	APHA 2340	232	mg/l	0 - 200
11	Calcium Ca2+ كالسيوم	APHA 2340	80	mg/l	0 - 100
12	MAGNESIUM - Mg2+ ماغنيسيوم	APHA 2340	7.8	mg/l	0 - 100
13	Iron - Fe 2+ & Fe 3+ حديد	APHA 4500-Fe	0.02	mg/l	< 0.3
14	Nitrate NO3- نترات	APHA 4500-NO3	0.4	mg/l	< 45
15	Total Chlorine الكلور مجموع	APHA 3120	1.58	mg/l	0 - 0.50
16	Free Chlorine الكلور الحر	APHA 3120	1.88	mg/l	0 - 0.50
17	Sodium - Na+ صوديوم	SM-3500-Na-B	132	mg/l	0 - 90
18	E. coli	ISO-9308-1:2014	<1	CFU/100 ml	< 1
19	Total Coliform بكتيريا	ISO-9308-1: 2014	<1	CFU/100 ml	< 1

ANALYSIS RESULTS

S	Parameter / Testing	Method	Result	Unit	STD
20	Legionella Spp	ISO 11731:2017	<1	CFU/ml	<1

REMARKS & COMMENTS

Based on the result, we would regard that the water sample doesn't meet the chemical satisfactory quality for domestic water and it is not recommended for drinking. Some parameters are above the recommended limit.



Lab Manager

Name & Signature