

## **Drinking Water Quality Certification – April 2016**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 7983  
**Reference:** 27-130  
**Date Sampled:** 20 Apr 2016  
**Date Reported:** 26 Apr 2016

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	20310	<1	<1	0.22	0.22
Andy Price	20311	<1	<1	0.22	0.22
Creche	20312	<1	<1	0.14	0.14
Michael Hogan	20313	<1	<1	0.22	0.22
School/Hall	20314	<1	<1	0.14	0.14
Sheedy's Shop	20315	<1	<1	0.15	0.15

**Drinking Water Quality Rating:** Please maintain free chlorine at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.