

Drinking Water Quality Certification – July 2019

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 922
Reference: 33-36
Date Sampled: 05 Jul 2019
Date Reported: 12 Jul 2019

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	24868	<1	<1	0.05	0.06
R Murphy	24869	<1	<1	0.24	0.29
Creche	24870	<1	<1	0.11	0.17
Michael Hogan	24871	<1	<1	0.18	0.21
School/Hall	24872	<1	<1	0.10	0.11
Sheedy's Shop	24873	<1	<1	0.14	0.17

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.