

## **Drinking Water Quality Certification – July 2017**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8386  
**Reference:** 29-138  
**Date Sampled:** 18 Jul 2017  
**Date Reported:** 25 Jul 2017

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21959	<1	<1	0.09	0.11
R Murphy	21960	<1	<1	0.16	0.20
Creche	21961	<1	<1	0.12	0.12
Michael Hogan	21962	<1	<1	0.19	0.19
School/Hall	21963	<1	<1	0.10	0.10
Sheedy's Shop	21964	<1	<1	0.09	0.09

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.