

### **Drinking Water Quality Certification – March 2020**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 9402  
**Reference:** 34-87/90  
**Date Sampled:** 05 Mar 2020  
**Date Reported:** 14 Mar 2020

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L	Total Hardness mg/L CaCO <sub>3</sub>
Pat Haren	25968	<1	<1	0.14	0.16	170
R Murphy	25969	<1	<1	0.06	0.10	185
Creche	25970	<1	<1	0.08	0.10	180
Michael Hogan	25971	<1	<1	0.27	0.30	170
School/Hall	25972	<1	<1	0.06	0.07	160
Londis Shop	25973	<1	<1	0.04	0.08	180

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.