

## **Drinking Water Quality Certification – October 2025**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 11983  
**Reference:** 44-3  
**Date Sampled:** 14 Oct 2025  
**Date Reported:** 21 Oct 2025

**Regulations:** SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	36505	<1	<1	0.50	0.65
R Murphy	36506	<1	<1	0.25	0.35
Michael Hogan	36507	<1	<1	0.25	0.34
School	36508	<1	<1	0.03	0.06
Londis Shop	36509	<1	<1	0.23	0.32
Banner Steel	36510	<1	<1	0.40	0.50

**Comment:**

It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.