

Drinking Water Quality Certification – August 2025

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 11910
Reference: 43-97
Date Sampled: 05 Aug 2025
Date Reported: 13 Aug 2025

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	36076	<1	<1	0.03	0.05
R Murphy	36077	<1	<1	0.04	0.05
Michael Hogan	36078	<1	<1	0.02	0.08
School	-	-	-	-	-
Londis Shop	36079	<1	<1	0.03	0.05
Banner Steel	36080	<1	<1	0.06	0.12

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.