

Drinking Water Quality Certification – October 2017

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8481
Reference: 30-56
Date Sampled: 23 Oct 2017
Date Reported: 30 Oct 2017

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	22375	<1	<1	0.16	0.16
R Murphy	22376	<1	<1	0.18	0.18
Creche	22377	<1	<1	0.16	0.18
Michael Hogan	22378	<1	<1	0.18	0.18
School/Hall	22379	<1	<1	0.17	0.20
Sheedy's Shop	22380	<1	<1	0.07	0.07

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.