

Drinking Water Quality Certification – January 2020

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9340
Reference: 34-30/32
Date Sampled: 08 Jan 2020
Date Reported: 11 Jan 2020

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L	Total Hardness mg/L CaCO ₃
Pat Haren	25668	<1	<1	0.07	0.09	150
R Murphy	25669	<1	<1	0.21	0.24	145
Creche	25670	<1	<1	0.06	0.06	135
Michael Hogan	25671	<1	<1	0.13	0.17	150
School/Hall	25672	<1	<1	0.03	0.05	150
Londis Shop	25673	<1	<1	0.06	0.09	140

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.