

## **Drinking Water Quality Certification – October 2018**

Killone GWS,  
Imleach,  
Barn tick,  
Ballynacally,  
Co. Clare.

**Report No:** 8817  
**Reference:** 31-175  
**Date Sampled:** 16 Oct 2018  
**Date Reported:** 22 Oct 2018

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	23821	<1	<1	0.10	0.17
R Murphy	23822	<1	<1	0.17	0.20
Creche	23823	<1	<1	0.17	0.24
Michael Hogan	23824	<1	<1	0.16	0.20
School/Hall	23825	<1	<1	0.08	0.14
Sheedy's Shop	23826	<1	<1	0.08	0.08

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.