

## **Drinking Water Quality Certification – November 2018**

Killone GWS,  
Imleach,  
Barntick,  
Ballynacally,  
Co. Clare.

**Report No:** 8852  
**Reference:** 32-11  
**Date Sampled:** 05 Nov 2018  
**Date Reported:** 25 Nov 2018

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	23902	<1	<1	0.05	0.07
R Murphy	23903	<1	<1	0.28	0.29
Creche	23904	<1	<1	0.07	0.11
Michael Hogan	23905	<1	<1	0.20	0.28
School/Hall	23906	<1	<1	0.05	0.06
Sheedy's Shop	23907	<1	<1	0.02	0.02

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.