

30/05/2015

Mr. Adrian Donnelly,
Treasurer Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No. 7679
Ref: 26-65

Dear Adrian,

Re: Drinking Water Quality Certification – May 2015

We examined six drinking water samples taken from the indicated locations on the 22/05/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

Regulations:


SI 278 of 2007 and the Drinking Water Directive.
Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	19223	<1	<1	1.60	1.60
Andy Price	19224	<1	<1	1.20	1.20
Creche	19225	<1	<1	1.20	1.20
Michael Hogan	19226	<1	<1	1.40	1.40
School/Hall	19227	<1	<1	1.40	1.50
Sheedy's Shop	19228	<1	<1	0.70	0.70

Drinking Water Quality Rating: Please continue to maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.