

Drinking Water Quality Certification – August 2016

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8107
Reference: 28-45
Date Sampled: 12 Aug 2016
Date Reported: 23 Aug 2016

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	20662	<1	<1	0.16	0.16
Andy Price	20663	<1	<1	0.10	0.20
Creche	20664	<1	<1	0.15	0.15
Michael Hogan	20665	<1	<1	0.24	0.24
School/Hall*	20666	<1	<1	0.20	0.29
Sheedy's Shop	20667	<1	<1	0.17	0.17

*This sample was taken from Rory Murphy's House

Drinking Water Quality Rating: Please continue to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.