

Drinking Water Quality Certification – January 2019

Killone GWS,
Imleach,
Barn tick,
Ballynacally,
Co. Clare.

Report No: 8917
Reference: 32-65
Date Sampled: 22 Jan 2019
Date Reported: 28 Jan 2019

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	24194	<1	<1	0.09	0.13
R Murphy	24195	<1	<1	0.16	0.20
Creche	24196	<1	<1	0.09	0.12
Michael Hogan	24197	<1	<1	0.13	0.18
School/Hall	24198	<1	<1	0.06	0.09
Sheedy's Shop	24199	<1	<1	0.07	0.07

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.