

Drinking Water Quality Certification – November 2022

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 10571
Reference: 38-183/185
Date Sampled: 07 Nov 2022
Date Reported: 16 Nov 2022

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	30069	<1	<1	0.23	0.24
R Murphy	30070	<1	<1	0.46	0.47
Michael Hogan	30071	<1	<1	0.45	0.45
School	30072	<1	<1	0.08	0.08
Londis Shop	30073	<1	<1	0.20	0.22
Banner Steel	30074	<1	<1	0.13	0.13

Comment: No Coliforms or *E. coli* were detected in the samples tested. It is recommended to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.