

Drinking Water Quality Certification – August 2018

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8755
Reference: 31-117
Date Sampled: 14 Aug 2018
Date Reported: 19 Aug 2018

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	23532	<1	<1	0.08	0.10
R Murphy	23533	<1	<1	0.18	0.23
Creche	23534	<1	<1	0.07	0.08
Michael Hogan	23535	<1	<1	0.16	0.20
School/Hall	23536	<1	<1	0.07	0.10
Sheedy's Shop	23537	<1	<1	0.08	0.11

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.