

## **Drinking Water Quality Certification – January 2018**

Killone GWS,  
Imleach,  
Barn tick,  
Ballynacally,  
Co. Clare.

**Report No:** 8532  
**Reference:** 30-118  
**Date Sampled:** 15 Jan 2018  
**Date Reported:** 27 Jan 2018

**Regulations:** SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	22666	<1	<1	0.06	0.08
R Murphy	22667	<1	<1	0.18	0.21
Creche	22668	<1	<1	0.12	0.15
Michael Hogan	22669	<1	<1	0.11	0.14
School/Hall	22670	<1	<1	0.11	0.15
Sheedy's Shop	22671	<1	<1	0.06	0.06

**Drinking Water Quality Rating:** Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan  
Amberley Water Solutions Ltd.