

Drinking Water Quality Certification – April 2021

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 9764
Reference: 35-123
Date Sampled: 07 Apr 2021
Date Reported: 10 Apr 2021

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

| Sample Location | Sample No. | Total Coliforms No./100 mL | <i>E. coli</i> No./100 mL | Free Chlorine mg/L | Total Chlorine mg/L |
|-----------------|------------|----------------------------|---------------------------|--------------------|---------------------|
| Pat Haren | 27126 | <1 | <1 | 0.10 | 0.14 |
| R Murphy | 27127 | <1 | <1 | 0.38 | 0.47 |
| Creche | 27128 | <1 | <1 | 0.12 | 0.18 |
| Michael Hogan | 27129 | <1 | <1 | 0.39 | 0.46 |
| School/Hall | - | - | - | - | - |
| Londis Shop | 27130 | <1 | <1 | 0.07 | 0.12 |

Comment: No Coliforms or *E. coli* were detected in the samples tested. Please continue to maintain free chlorine at approx. 0.2 mg/L.

School was not open at the time of sampling.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.