

Drinking Water Quality Certification – April 2018

Killone GWS,
Imleach,
Barn tick,
Ballynacally,
Co. Clare.

Report No: 8624
Reference: 31-40
Date Sampled: 23 Apr 2018
Date Reported: 05 May 2018

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	23118	<1	<1	0.18	0.18
R Murphy	23119	<1	<1	0.37	0.41
Creche	23120	<1	<1	0.22	0.24
Michael Hogan	23121	<1	<1	0.35	0.40
School/Hall	23122	<1	<1	0.10	0.12
Sheedy's Shop	23123	<1	<1	0.14	0.18

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.